



IEC 60287-2-3

Edition 2.0 2024-06
REDLINE VERSION

INTERNATIONAL STANDARD



**Electric cables – Calculation of the current rating –
Part 2-3: Thermal resistance – Cables installed in ventilated tunnels**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.060.20

ISBN 978-2-8322-9370-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	2
1 Scope.....	7
2 Normative references	7
3 Terms, definitions and symbols.....	7
3.1 Terms and definitions.....	7
3.2 Symbols.....	8
4 Description of method.....	9
4.1 General description.....	9
4.2 Basic formulae	10
4.2.1 General	10
4.2.2 Radial heat transfer by conduction within the cable	11
4.2.3 Heat transfer by radiation from the cable surface to the inner wall of the tunnel	11
4.2.4 Heat transfer by convection from the cable surface to the air inside the tunnel	12
4.2.5 Heat transfer by convection from the air inside the tunnel to the inner tunnel wall	14
4.2.6 Longitudinal heat transfer by convection resulting from the forced or natural flow of air along the tunnel	14
4.2.7 Radial heat conduction in the soil surrounding the tunnel.....	15
4.3 Set of formulae	16
4.4 Solving	17
4.5 Iterative process	19
5 Formulae for air properties	20
6 Temperature profile	20
Annex A (informative) Calculation example	22
A.1 Cable and installation	22
A.2 Calculated values	22
Annex B (informative) Delta-star transformation.....	25
Annex C (informative) Calculation of F_{m} C_{Fm} coefficient.....	27
C.1 Definition of spacing	27
C.2 Calculation of C_{Fm} coefficient.....	27
Bibliography.....	29
Figure A.1 – Temperature profile along a 1 km tunnel.....	24
Figure A.2 – Temperature profile along a 10 km tunnel.....	24
Figure B.1 – Delta-star transformation	26
Figure C.1 – Spacing definitions	27
Table 1 – F_{m} C_{Fm} coefficient for radiation thermal resistance calculation.....	12
Table 2 – Values of parameter K_{CV}	14
Table A.1 – Installation data	22
Table A.2 – Iterative process for a 1 km long tunnel.....	23

Table C.1 – Expression for F_m C_{F_m} coefficient calculation28



INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRIC CABLES –
CALCULATION OF THE CURRENT RATING –****Part 2-3: Thermal resistance – Cables installed in ventilated tunnels****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC 60287-2-3:2017. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC 60287-2-3 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This second edition cancels and replaces the first edition published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) symbols alignment with other parts of the IEC 60287 series.

The text of this International Standard is based on the following documents:

Draft	Report on voting
20/2175/FDIS	20/2182/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

In the IEC 60287 series, IEC 60287-1 provides general formulae for ratings and power losses of electric cables.

The IEC 60287-2 series presents formulae or calculation methods for thermal resistances.

IEC 60287-2-1 provides calculation methods for dealing with cables installed in free air (see IEC 60287-2-1:2015, 4.2.1).

IEC 60287-2-2 provides a method and data for calculating reduction factors for cables in groups running horizontally in free air.

IEC 60287-2-1 and IEC 60287-2-2 consider heat transfer only in a plane perpendicular to the cables; they assume there is no longitudinal heat transfer.

This part of IEC 60287 deals with the rating for cables installed in ventilated tunnels. In such situations, consideration of longitudinal temperature gradients is involved as the air flowing in the tunnel removes some heat from the cables.

Heat transfer with the moving air is convective and is assumed to be either laminar or turbulent depending on the air velocity. The transition situation between laminar and turbulent air flows is ignored.

A general simplified method is provided to estimate the permissible current-carrying capacity of cables installed in ventilated tunnels, the ventilation being either natural or forced.

Only steady states are considered, where the inlet air temperature and the cable loading are constant for a sufficient time for steady temperatures to be achieved.

Where multiple circuits are involved, their characteristics are assumed to be identical.

The main features of the calculation method for cables in tunnels with forced ventilation can be found in Electra n°143 – 144 (1992)[1]¹, as the report of a CIGRE working group, including the erratum in Electra n°209 (2003).

¹ Numbers in square brackets refer to the Bibliography.

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 2-3: Thermal resistance – Cables installed in ventilated tunnels

1 Scope

This part of IEC 60287 describes a method for calculating the continuous current rating factor for cables of all voltages installed in ventilated tunnels. The method is applicable to any type of cable.

The method applies to natural as well as forced ventilation.

Longitudinal heat transfer within the cables and the surroundings of the tunnel is assumed to be negligible.

All cables are assumed to be identical within the tunnel and it is assumed that the tunnel cross-section does not change with distance along the tunnel.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60287-1-1, *Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General*

IEC 60287-2-1:~~2015~~, *Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of thermal resistance*

INTERNATIONAL STANDARD

**Electric cables – Calculation of the current rating –
Part 2-3: Thermal resistance – Cables installed in ventilated tunnels**



CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions and symbols.....	7
3.1 Terms and definitions.....	7
3.2 Symbols.....	8
4 Description of method.....	9
4.1 General description.....	9
4.2 Basic formulae	10
4.2.1 General	10
4.2.2 Radial heat transfer by conduction within the cable	11
4.2.3 Heat transfer by radiation from the cable surface to the inner wall of the tunnel	11
4.2.4 Heat transfer by convection from the cable surface to the air inside the tunnel	12
4.2.5 Heat transfer by convection from the air inside the tunnel to the inner tunnel wall	13
4.2.6 Longitudinal heat transfer by convection resulting from the forced or natural flow of air along the tunnel	14
4.2.7 Radial heat conduction in the soil surrounding the tunnel.....	14
4.3 Set of formulae	15
4.4 Solving	16
4.5 Iterative process	17
5 Formulae for air properties	17
6 Temperature profile	18
Annex A (informative) Calculation example	19
A.1 Cable and installation	19
A.2 Calculated values	19
Annex B (informative) Delta-star transformation.....	22
Annex C (informative) Calculation of C_{F_m} coefficient.....	23
C.1 Definition of spacing	23
C.2 Calculation of C_{F_m} coefficient	23
Bibliography.....	25
Figure A.1 – Temperature profile along a 1 km tunnel	21
Figure A.2 – Temperature profile along a 10 km tunnel	21
Figure B.1 – Delta-star transformation	22
Figure C.1 – Spacing definitions	23
Table 1 – C_{F_m} coefficient for radiation thermal resistance calculation	12
Table 2 – Values of parameter K_{CV}	13
Table A.1 – Installation data	19
Table A.2 – Iterative process for a 1 km long tunnel.....	20

Table C.1 – Expression for C_{F_m} coefficient calculation.....23

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 2-3: Thermal resistance – Cables installed in ventilated tunnels

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60287-2-3 has been prepared by IEC technical committee 20: Electric cables. It is an International Standard.

This second edition cancels and replaces the first edition published in 2017. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) symbols alignment with other parts of the IEC 60287 series.

The text of this International Standard is based on the following documents:

Draft	Report on voting
20/2175/FDIS	20/2182/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60287 series, published under the general title *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

In the IEC 60287 series, IEC 60287-1 provides general formulae for ratings and power losses of electric cables.

The IEC 60287-2 series presents formulae or calculation methods for thermal resistances.

IEC 60287-2-1 provides calculation methods for dealing with cables installed in free air (see IEC 60287-2-1:2015, 4.2.1).

IEC 60287-2-2 provides a method and data for calculating reduction factors for cables in groups running horizontally in free air.

IEC 60287-2-1 and IEC 60287-2-2 consider heat transfer only in a plane perpendicular to the cables; they assume there is no longitudinal heat transfer.

This part of IEC 60287 deals with the rating for cables installed in ventilated tunnels. In such situations, consideration of longitudinal temperature gradients is involved as the air flowing in the tunnel removes some heat from the cables.

Heat transfer with the moving air is convective and is assumed to be either laminar or turbulent depending on the air velocity. The transition situation between laminar and turbulent air flows is ignored.

A general simplified method is provided to estimate the permissible current-carrying capacity of cables installed in ventilated tunnels, the ventilation being either natural or forced.

Only steady states are considered, where the inlet air temperature and the cable loading are constant for a sufficient time for steady temperatures to be achieved.

Where multiple circuits are involved, their characteristics are assumed to be identical.

The main features of the calculation method for cables in tunnels with forced ventilation can be found in Electra n°143 – 144 (1992)[1]¹, as the report of a CIGRE working group, including the erratum in Electra n°209 (2003).

¹ Numbers in square brackets refer to the Bibliography.

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 2-3: Thermal resistance – Cables installed in ventilated tunnels

1 Scope

This part of IEC 60287 describes a method for calculating the continuous current rating factor for cables of all voltages installed in ventilated tunnels. The method is applicable to any type of cable.

The method applies to natural as well as forced ventilation.

Longitudinal heat transfer within the cables and the surroundings of the tunnel is assumed to be negligible.

All cables are assumed to be identical within the tunnel and it is assumed that the tunnel cross-section does not change with distance along the tunnel.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60287-1-1, *Electric cables – Calculation of the current rating – Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General*

IEC 60287-2-1, *Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of thermal resistance*