



IEC 60364-5-52

Edition 3.1 2024-11  
CONSOLIDATED VERSION

# INTERNATIONAL STANDARD



---

**Low-voltage electrical installations –  
Part 5-52: Selection and erection of electrical equipment – Wiring systems**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 13.260, 91.140.50

ISBN 978-2-8327-0055-6

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	6
520 Introduction.....	8
520.1 Scope.....	8
520.2 Normative references.....	8
520.3 Terms and definitions.....	9
520.4 General.....	10
521 Types of wiring system.....	10
521.4 Busbar trunking systems and powertrack systems.....	10
521.5 AC circuits – Electromagnetic effects (prevention of eddy current).....	10
521.6 Conduit systems, cable ducting systems, cable trunking systems, cable tray systems and cable ladder systems.....	10
521.7 Several circuits in one cable.....	11
521.8 Circuit arrangements.....	11
521.9 Use of flexible cables or cords.....	11
521.10 Installation of cables.....	11
522 Selection and erection of wiring systems in relation to external influences.....	11
522.1 Ambient temperature (AA).....	12
522.2 External heat sources.....	12
522.3 Presence of water (AD) or high humidity (AB).....	12
522.4 Presence of solid foreign bodies (AE).....	12
522.5 Presence of corrosive or polluting substances (AF).....	13
522.6 Impact (AG).....	13
522.7 Vibration (AH).....	13
522.8 Other mechanical stresses (AJ).....	13
522.9 Presence of flora and/or mould growth (AK).....	15
522.10 Presence of fauna (AL).....	15
522.11 Solar radiation (AN) and ultraviolet radiation.....	15
522.12 Seismic effects (AP).....	15
522.13 Wind (AR).....	15
522.14 Nature of processed or stored materials (BE).....	15
522.15 Building design (CB).....	15
523 Current-carrying capacities.....	16
523.5 Groups containing more than one circuit.....	17
523.6 Number of loaded conductors.....	17
523.7 Conductors in parallel.....	17
523.8 Variation of installation conditions along a route.....	18
523.9 Single-core cables with a metallic covering.....	18
524 Cross-sectional areas of conductors.....	18
524.2 Cross-sectional area of the neutral conductor.....	19
524.3 Cross-sectional area of live conductors with triplen harmonics.....	20
525 Voltage drop in consumers' installations.....	20
526 Electrical connections.....	20
526.8 Connection of multi wire, fine wire and very fine wire conductors.....	21
527 Selection and erection of wiring systems to minimize the spread of fire.....	22
527.1 Precautions within a fire-segregated compartment.....	22
527.2 Sealing of wiring system penetrations.....	22

528 Proximity of wiring systems to other services .....	23
528.1 Proximity to electrical services.....	23
528.2 Proximity of communications cables .....	24
528.3 Proximity to non-electrical services.....	24
529 Selection and erection of wiring systems in relation to maintainability, including cleaning .....	24
Annex A (normative) Methods of installations.....	26
Annex B (informative) Current-carrying capacities .....	35
Annex C (informative) Example of a method of simplification of the tables of Clause 523 .....	64
Annex D (informative) Formulae to express current-carrying capacities .....	68
Annex E (normative) Effect of harmonic currents on balanced three-phase systems .....	72
Annex F (informative) Selection of conduit systems .....	78
Annex G (informative) Voltage drop in consumers' installations .....	79
Annex H (informative) Examples of configurations of parallel cables.....	81
Annex I (informative) List of notes concerning certain countries .....	84
Bibliography.....	89
Figure H.52.1 – Special configuration for 6 parallel single-core cables in a flat plane (see 523.7) .....	81
Figure H.52.2 – Special configuration for 6 parallel single-core cables above each other (see 523.7) .....	81
Figure H.52.3 – Special configuration for 6 parallel single-core cables in trefoil (see 523.7) .....	82
Figure H.52.4 – Special configuration for 9 parallel single-core cables in a flat plane (see 523.7) .....	82
Figure H.52.5 – Special configuration for 9 parallel single-core cables above each other (see 523.7) .....	82
Figure H.52.6 – Special configuration for 9 parallel single-core cables in trefoil (see 523.7) .....	83
Figure H.52.7 – Special configuration for 12 parallel single-core cables in a flat plane (see 523.7) .....	83
Figure H.52.8 – Special configuration for 12 parallel single-core cables above each other (see 523.7) .....	83
Figure H.52.9 – Special configuration for 12 parallel single-core cables in trefoil (see 523.7) .....	83
Table 52.1 – Maximum operating temperatures for types of insulation .....	16
Table 52.2 – Minimum cross-sectional area of conductors .....	19
Table A.52.1 – Methods of installation in relation to conductors and cables .....	26
Table A.52.2 – Erection of wiring systems.....	27
Table A.52.3 – Examples of methods of installation providing instructions for obtaining current-carrying capacity .....	28
Table B.52.1 – Installation reference methods forming basis of tabulated current- carrying capacities .....	40
Table B.52.2 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – PVC insulation/two loaded conductors, copper or aluminium – Conductor temperature: 70 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	42

Table B.52.3 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – XLPE or EPR insulation, two loaded conductors/copper or aluminium – Conductor temperature: 90 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	43
Table B.52.4 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – PVC insulation, three loaded conductors/copper or aluminium – Conductor temperature: 70 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	44
Table B.52.5 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – XLPE or EPR insulation, three loaded conductors/copper or aluminium – Conductor temperature: 90 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	45
Table B.52.6 – Current-carrying capacities in amperes for installation method C of Table B.52.1 – Mineral insulation, copper conductors and sheath – PVC covered or bare exposed to touch (see note 2) – Metallic sheath temperature: 70 °C, reference ambient temperature: 30 °C .....	46
Table B.52.7 – Current-carrying capacities in amperes for installation method C of Table B.52.1 – Mineral insulation, copper conductors and sheath – Bare cable not exposed to touch and not in contact with combustible material Metallic sheath temperature: 105 °C, reference ambient temperature: 30 °C .....	47
Table B.52.8 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – Mineral insulation, copper conductors and sheath/PVC covered or bare exposed to touch (see note 2) – Metallic sheath temperature: 70 °C, reference ambient temperature: 30 °C .....	48
Table B.52.9 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – Mineral insulation, copper conductors and sheath – Bare cable not exposed to touch (see note 2) – Metallic sheath temperature: 105 °C, reference ambient temperature: 30 °C .....	49
Table B.52.10 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – PVC insulation, copper conductors – Conductor temperature: 70 °C, reference ambient temperature: 30 °C.....	50
Table B.52.11 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – PVC insulation, aluminium conductors – Conductor temperature: 70 °C, reference ambient temperature: 30 °C.....	51
Table B.52.12 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – XLPE or EPR insulation, copper conductors – Conductor temperature: 90 °C, reference ambient temperature: 30 °C .....	52
Table B.52.13 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – XLPE or EPR insulation. aluminium conductors – Conductor temperature: 90 °C, reference ambient temperature: 30 °C.....	53
Table B.52.14 – Correction factor for ambient air temperatures other than 30 °C to be applied to the current-carrying capacities for cables in the air .....	54
Table B.52.15 – Correction factors for ambient ground temperatures other than 20 °C to be applied to the current-carrying capacities for cables in ducts in the ground .....	55
Table B.52.16 – Correction factors for cables buried direct in the ground or in buried ducts for soil thermal resistivities other than 2,5 K · m/W to be applied to the current-carrying capacities for reference method D .....	55
Table B.52.17 – Reduction factors for one circuit or one multi-core cable or for a group of more than one circuit, or more than one multi-core cable, to be used with current-carrying capacities of Tables B.52.2 to B.52.13 .....	56
Table B.52.18 – Reduction factors for more than one circuit, cables laid directly in the ground – Installation method D2 in Tables B.52.2 to B.52.5 – Single-core or multi-core cables.....	57
Table B.52.19 – Reduction factors for more than one circuit, cables laid in ducts in the ground – Installation method D1 in Tables B.52.2 to B.52.5 .....	58

Table B.52.20 – Reduction factors for group of more than one multi-core cable to be applied to reference current-carrying capacities for multi-core cables in free air – Method of installation E in Tables B.52.8 to B.52.13 ..... 60

Table B.52.21 – Reduction factors for groups of one or more circuits of single-core cables to be applied to reference current-carrying capacity for one circuit of single-core cables in free air – Method of installation F in Tables B.52.8 to B.52.13..... 62

Table C.52.1 – Current-carrying capacity in amperes ..... 65

Table C.52.2 – Current-carrying capacities in amperes ..... 66

Table C.52.3– Reduction factors for groups of several circuits or of several multi-core cables (to be used with current-carrying capacities of Table C.52.1) ..... 67

Table D.52.1 – Table of coefficients and exponents ..... 69

Table E.52.1 – Reduction factors ~~for harmonic currents in four-core and five-core cables~~ ..... 75

Table F.52.1 – Suggested characteristics for conduit (classification according to IEC 61386) ..... 78

Table G.52.1 – Voltage drop ..... 79

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**LOW-VOLTAGE ELECTRICAL INSTALLATIONS –****Part 5-52: Selection and erection of electrical equipment –  
Wiring systems**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

**This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.**

**IEC 60364-5-52 edition 3.1 contains the third edition (2009-10) [documents 64/1685/FDIS and 64/1705/RVD], its corrigendum 1 (2011-02) and its amendment 1 (2024-11) [documents 64/2675/FDIS and 64/2703/RVD].**

**In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.**

International Standard IEC 60364-5-52 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This third edition cancels and replaces the second edition, published in 2001, and constitutes a technical revision.

The main changes with respect to the previous edition are as follows:

- Subclause 521.4 introduces minor changes with regard to busbar trunking systems and powertrack systems.
- Subclause 523.6 introduces minor changes with regard to the sizing of cables where harmonic currents are present.
- A new subclause 523.9 concerning single-core cables with a metallic covering has been introduced.
- Clause 525 introduces changes in the maximum value of voltage drop permitted between the origin of the consumer's installation and the equipment which should not be greater than that given in the relevant annex.
- Clause 526 introduces minor changes to electrical connections including additional exceptions for inspection of connections and additional notes.
- Clause 528 introduces additional requirements with regard to proximity of underground power and telecommunication cables.
- Clause 529 introduces minor changes to selection and erection of wiring systems in relation to maintainability, including cleaning.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex I lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this standard.

A list of all the parts in the IEC 602364 series, under the general title *Low-voltage electrical installations*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

### Part 5-52: Selection and erection of electrical equipment – Wiring systems

#### 520 Introduction

##### 520.1 Scope

Part 5-52 of IEC 60364 deals with the selection and erection of wiring systems.

NOTE 1 This standard also applies in general to protective conductors, while IEC 60364-5-54 contains further requirements for those conductors.

NOTE 2 Guidance on Part 5-52 of IEC 60364 is given in IEC 61200-52.

##### 520.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60228, *Conductors of insulated cables*

IEC 60287 (all parts), *Electric cables – Calculation of the current rating*

IEC 60287-2-1, *Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of thermal resistance*<sup>1</sup>

IEC 60287-3-1, *Electric cables – Calculation of the current rating – Part 3-1: Sections on operating conditions – Reference operating conditions and selection of cable type*<sup>2</sup>

IEC 60332-1-1, *Tests on electric and optical fibre cables under fire conditions – Part 1-1: Test for vertical flame propagation for a single insulated wire or cable – Apparatus*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60364-1:2005, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-4-42, *Electrical installations of buildings – Part 4-42: Protection for safety – Protection against thermal effects*

---

<sup>1</sup> A consolidated edition 1.2 exists (2006) that includes IEC 60287-2-1 (1994) and its amendments 1 and 2 (1999 and 2006).

<sup>2</sup> A consolidated edition 1.1 exists (1999) that includes IEC 60287-3-1 (1995) and its amendment 1 (1999).



IEC 60364-4-43:2023, *Low-voltage electrical installations – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 60364-5-54, *Electrical installations of buildings – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements, protective conductors and protective bonding conductors*

IEC 60439-2, *Low-voltage switchgear and controlgear assemblies – Part 2: Particular requirements for busbar trunking systems (busways)*<sup>3</sup>

IEC 60449, *Voltage bands for electrical installations of buildings*

IEC 60502 (all parts), *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ( $U_m = 1,2$  kV) up to 30 kV ( $U_m = 36$  kV)*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*<sup>4</sup>

IEC 60570, *Electrical supply track systems for luminaires*

IEC 60702 (all parts), *Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V*

IEC 60947-7 (all parts 7), *Low-voltage switchgear and controlgear – Part 7: Ancillary equipment*

IEC 60998 (all parts), *Connecting devices for low-voltage circuits for household and similar purposes*

IEC 61084 (all parts), *Cable trunking and ducting systems for electrical installations*

IEC 61386 (all parts), *Conduit systems for cable management*

IEC 61534 (all parts), *Powertrack systems*

IEC 61537, *Cable management – Cable tray systems and cable ladder systems*

ISO 834 (all parts), *Fire-resistance tests – Elements of building construction*

---

<sup>3</sup> A consolidated edition 3.1 exists (2005) that includes IEC 60439-2 (1995) and its amendment 1 (2005).

<sup>4</sup> A consolidated edition 2.1 exists (2001) that includes IEC 60529 (1989) and its amendment 1 (1999).

## CONTENTS

FOREWORD.....	6
520 Introduction.....	8
520.1 Scope.....	8
520.2 Normative references.....	8
520.3 Terms and definitions.....	9
520.4 General.....	10
521 Types of wiring system.....	10
521.4 Busbar trunking systems and powertrack systems.....	10
521.5 AC circuits – Electromagnetic effects (prevention of eddy current).....	10
521.6 Conduit systems, cable ducting systems, cable trunking systems, cable tray systems and cable ladder systems.....	10
521.7 Several circuits in one cable.....	11
521.8 Circuit arrangements.....	11
521.9 Use of flexible cables or cords.....	11
521.10 Installation of cables.....	11
522 Selection and erection of wiring systems in relation to external influences.....	11
522.1 Ambient temperature (AA).....	12
522.2 External heat sources.....	12
522.3 Presence of water (AD) or high humidity (AB).....	12
522.4 Presence of solid foreign bodies (AE).....	12
522.5 Presence of corrosive or polluting substances (AF).....	13
522.6 Impact (AG).....	13
522.7 Vibration (AH).....	13
522.8 Other mechanical stresses (AJ).....	13
522.9 Presence of flora and/or mould growth (AK).....	15
522.10 Presence of fauna (AL).....	15
522.11 Solar radiation (AN) and ultraviolet radiation.....	15
522.12 Seismic effects (AP).....	15
522.13 Wind (AR).....	15
522.14 Nature of processed or stored materials (BE).....	15
522.15 Building design (CB).....	15
523 Current-carrying capacities.....	16
523.5 Groups containing more than one circuit.....	17
523.6 Number of loaded conductors.....	17
523.7 Conductors in parallel.....	17
523.8 Variation of installation conditions along a route.....	18
523.9 Single-core cables with a metallic covering.....	18
524 Cross-sectional areas of conductors.....	18
524.2 Cross-sectional area of the neutral conductor.....	19
524.3 Cross-sectional area of live conductors with triplen harmonics.....	19
525 Voltage drop in consumers' installations.....	20
526 Electrical connections.....	20
526.8 Connection of multi wire, fine wire and very fine wire conductors.....	21
527 Selection and erection of wiring systems to minimize the spread of fire.....	21
527.1 Precautions within a fire-segregated compartment.....	21
527.2 Sealing of wiring system penetrations.....	21

528 Proximity of wiring systems to other services .....	22
528.1 Proximity to electrical services.....	22
528.2 Proximity of communications cables .....	23
528.3 Proximity to non-electrical services.....	23
529 Selection and erection of wiring systems in relation to maintainability, including cleaning .....	24
Annex A (normative) Methods of installations.....	25
Annex B (informative) Current-carrying capacities .....	34
Annex C (informative) Example of a method of simplification of the tables of Clause 523 .....	63
Annex D (informative) Formulae to express current-carrying capacities .....	67
Annex E (normative) Effect of harmonic currents on balanced three-phase systems .....	71
Annex F (informative) Selection of conduit systems .....	75
Annex G (informative) Voltage drop in consumers' installations .....	76
Annex H (informative) Examples of configurations of parallel cables.....	78
Annex I (informative) List of notes concerning certain countries .....	81
Bibliography.....	86
Figure H.52.1 – Special configuration for 6 parallel single-core cables in a flat plane (see 523.7) .....	78
Figure H.52.2 – Special configuration for 6 parallel single-core cables above each other (see 523.7) .....	78
Figure H.52.3 – Special configuration for 6 parallel single-core cables in trefoil (see 523.7) .....	79
Figure H.52.4 – Special configuration for 9 parallel single-core cables in a flat plane (see 523.7) .....	79
Figure H.52.5 – Special configuration for 9 parallel single-core cables above each other (see 523.7) .....	79
Figure H.52.6 – Special configuration for 9 parallel single-core cables in trefoil (see 523.7) .....	80
Figure H.52.7 – Special configuration for 12 parallel single-core cables in a flat plane (see 523.7) .....	80
Figure H.52.8 – Special configuration for 12 parallel single-core cables above each other (see 523.7) .....	80
Figure H.52.9 – Special configuration for 12 parallel single-core cables in trefoil (see 523.7) .....	80
Table 52.1 – Maximum operating temperatures for types of insulation .....	16
Table 52.2 – Minimum cross-sectional area of conductors .....	19
Table A.52.1 – Methods of installation in relation to conductors and cables .....	25
Table A.52.2 – Erection of wiring systems.....	26
Table A.52.3 – Examples of methods of installation providing instructions for obtaining current-carrying capacity .....	27
Table B.52.1 – Installation reference methods forming basis of tabulated current- carrying capacities .....	39
Table B.52.2 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – PVC insulation/two loaded conductors, copper or aluminium – Conductor temperature: 70 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	41

Table B.52.3 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – XLPE or EPR insulation, two loaded conductors/copper or aluminium – Conductor temperature: 90 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	42
Table B.52.4 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – PVC insulation, three loaded conductors/copper or aluminium – Conductor temperature: 70 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	43
Table B.52.5 – Current-carrying capacities in amperes for methods of installation in Table B.52.1 – XLPE or EPR insulation, three loaded conductors/copper or aluminium – Conductor temperature: 90 °C, ambient temperature: 30 °C in air, 20 °C in ground.....	44
Table B.52.6 – Current-carrying capacities in amperes for installation method C of Table B.52.1 – Mineral insulation, copper conductors and sheath – PVC covered or bare exposed to touch (see note 2) – Metallic sheath temperature: 70 °C, reference ambient temperature: 30 °C .....	45
Table B.52.7 – Current-carrying capacities in amperes for installation method C of Table B.52.1 – Mineral insulation, copper conductors and sheath – Bare cable not exposed to touch and not in contact with combustible material Metallic sheath temperature: 105 °C, reference ambient temperature: 30 °C .....	46
Table B.52.8 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – Mineral insulation, copper conductors and sheath/PVC covered or bare exposed to touch (see note 2) – Metallic sheath temperature: 70 °C, reference ambient temperature: 30 °C .....	47
Table B.52.9 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – Mineral insulation, copper conductors and sheath – Bare cable not exposed to touch (see note 2) – Metallic sheath temperature: 105 °C, reference ambient temperature: 30 °C .....	48
Table B.52.10 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – PVC insulation, copper conductors – Conductor temperature: 70 °C, reference ambient temperature: 30 °C.....	49
Table B.52.11 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – PVC insulation, aluminium conductors – Conductor temperature: 70 °C, reference ambient temperature: 30 °C.....	50
Table B.52.12 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – XLPE or EPR insulation, copper conductors – Conductor temperature: 90 °C, reference ambient temperature: 30 °C.....	51
Table B.52.13 – Current-carrying capacities in amperes for installation methods E, F and G of Table B.52.1 – XLPE or EPR insulation. aluminium conductors – Conductor temperature: 90 °C, reference ambient temperature: 30 °C.....	52
Table B.52.14 – Correction factor for ambient air temperatures other than 30 °C to be applied to the current-carrying capacities for cables in the air .....	53
Table B.52.15 – Correction factors for ambient ground temperatures other than 20 °C to be applied to the current-carrying capacities for cables in ducts in the ground .....	54
Table B.52.16 – Correction factors for cables buried direct in the ground or in buried ducts for soil thermal resistivities other than 2,5 K · m/W to be applied to the current-carrying capacities for reference method D .....	54
Table B.52.17 – Reduction factors for one circuit or one multi-core cable or for a group of more than one circuit, or more than one multi-core cable, to be used with current-carrying capacities of Tables B.52.2 to B.52.13 .....	55
Table B.52.18 – Reduction factors for more than one circuit, cables laid directly in the ground – Installation method D2 in Tables B.52.2 to B.52.5 – Single-core or multi-core cables.....	56
Table B.52.19 – Reduction factors for more than one circuit, cables laid in ducts in the ground – Installation method D1 in Tables B.52.2 to B.52.5 .....	57

Table B.52.20 – Reduction factors for group of more than one multi-core cable to be applied to reference current-carrying capacities for multi-core cables in free air – Method of installation E in Tables B.52.8 to B.52.13 .....	59
Table B.52.21 – Reduction factors for groups of one or more circuits of single-core cables to be applied to reference current-carrying capacity for one circuit of single-core cables in free air – Method of installation F in Tables B.52.8 to B.52.13.....	61
Table C.52.1 – Current-carrying capacity in amperes .....	64
Table C.52.2 – Current-carrying capacities in amperes .....	65
Table C.52.3– Reduction factors for groups of several circuits or of several multi-core cables (to be used with current-carrying capacities of Table C.52.1) .....	66
Table D.52.1 – Table of coefficients and exponents .....	68
Table E.52.1 – Reduction factors.....	72
Table F.52.1 – Suggested characteristics for conduit (classification according to IEC 61386) .....	75
Table G.52.1 – Voltage drop .....	76

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**LOW-VOLTAGE ELECTRICAL INSTALLATIONS –****Part 5-52: Selection and erection of electrical equipment –  
Wiring systems**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

**This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.**

**IEC 60364-5-52 edition 3.1 contains the third edition (2009-10) [documents 64/1685/FDIS and 64/1705/RVD], its corrigendum 1 (2011-02) and its amendment 1 (2024-11) [documents 64/2675/FDIS and 64/2703/RVD].**

**This Final version does not show where the technical content is modified by amendment 1. A separate Redline version with all changes highlighted is available in this publication.**

International Standard IEC 60364-5-52 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This third edition cancels and replaces the second edition, published in 2001, and constitutes a technical revision.

The main changes with respect to the previous edition are as follows:

- Subclause 521.4 introduces minor changes with regard to busbar trunking systems and powertrack systems.
- Subclause 523.6 introduces minor changes with regard to the sizing of cables where harmonic currents are present.
- A new subclause 523.9 concerning single-core cables with a metallic covering has been introduced.
- Clause 525 introduces changes in the maximum value of voltage drop permitted between the origin of the consumer's installation and the equipment which should not be greater than that given in the relevant annex.
- Clause 526 introduces minor changes to electrical connections including additional exceptions for inspection of connections and additional notes.
- Clause 528 introduces additional requirements with regard to proximity of underground power and telecommunication cables.
- Clause 529 introduces minor changes to selection and erection of wiring systems in relation to maintainability, including cleaning.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex I lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this standard.

A list of all the parts in the IEC 602364 series, under the general title *Low-voltage electrical installations*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this document and its amendment will remain unchanged until the stability date indicated on the IEC website under [webstore.iec.ch](http://webstore.iec.ch) in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

## LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

### Part 5-52: Selection and erection of electrical equipment – Wiring systems

#### 520 Introduction

##### 520.1 Scope

Part 5-52 of IEC 60364 deals with the selection and erection of wiring systems.

NOTE 1 This standard also applies in general to protective conductors, while IEC 60364-5-54 contains further requirements for those conductors.

NOTE 2 Guidance on Part 5-52 of IEC 60364 is given in IEC 61200-52.

##### 520.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60228, *Conductors of insulated cables*

IEC 60287 (all parts), *Electric cables – Calculation of the current rating*

IEC 60287-2-1, *Electric cables – Calculation of the current rating – Part 2-1: Thermal resistance – Calculation of thermal resistance*<sup>1</sup>

IEC 60287-3-1, *Electric cables – Calculation of the current rating – Part 3-1: Sections on operating conditions – Reference operating conditions and selection of cable type*<sup>2</sup>

IEC 60332-1-1, *Tests on electric and optical fibre cables under fire conditions – Part 1-1: Test for vertical flame propagation for a single insulated wire or cable – Apparatus*

IEC 60332-1-2, *Tests on electric and optical fibre cables under fire conditions – Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame*

IEC 60364-1:2005, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-4-42, *Electrical installations of buildings – Part 4-42: Protection for safety – Protection against thermal effects*

---

<sup>1</sup> A consolidated edition 1.2 exists (2006) that includes IEC 60287-2-1 (1994) and its amendments 1 and 2 (1999 and 2006).

<sup>2</sup> A consolidated edition 1.1 exists (1999) that includes IEC 60287-3-1 (1995) and its amendment 1 (1999).



© IEC 2024

IEC 60364-4-43:2023, *Low-voltage electrical installations – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 60364-5-54, *Electrical installations of buildings – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements, protective conductors and protective bonding conductors*

IEC 60439-2, *Low-voltage switchgear and controlgear assemblies – Part 2: Particular requirements for busbar trunking systems (busways)*<sup>3</sup>

IEC 60449, *Voltage bands for electrical installations of buildings*

IEC 60502 (all parts), *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ( $U_m = 1,2$  kV) up to 30 kV ( $U_m = 36$  kV)*

IEC 60529, *Degrees of protection provided by enclosures (IP Code)*<sup>4</sup>

IEC 60570, *Electrical supply track systems for luminaires*

IEC 60702 (all parts), *Mineral insulated cables and their terminations with a rated voltage not exceeding 750 V*

IEC 60947-7 (all parts 7), *Low-voltage switchgear and controlgear – Part 7: Ancillary equipment*

IEC 60998 (all parts), *Connecting devices for low-voltage circuits for household and similar purposes*

IEC 61084 (all parts), *Cable trunking and ducting systems for electrical installations*

IEC 61386 (all parts), *Conduit systems for cable management*

IEC 61534 (all parts), *Powertrack systems*

IEC 61537, *Cable management – Cable tray systems and cable ladder systems*

ISO 834 (all parts), *Fire-resistance tests – Elements of building construction*

---

<sup>3</sup> A consolidated edition 3.1 exists (2005) that includes IEC 60439-2 (1995) and its amendment 1 (2005).

<sup>4</sup> A consolidated edition 2.1 exists (2001) that includes IEC 60529 (1989) and its amendment 1 (1999).