



IEC 60364-5-53

Edition 4.2 2024-12
CONSOLIDATED VERSION

INTERNATIONAL STANDARD



**Low-voltage electrical installations –
Part 5-53: Selection and erection of electrical equipment – Devices for protection
for safety, isolation, switching, control and monitoring**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.01, 91.140.50

ISBN 978-2-8327-0119-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	7
530.1 Scope	9
530.2 Normative references.....	9
530.3 Terms and definitions.....	12
530.4 General and common requirements.....	15
530.5 Erection of equipment.....	15
531 Devices for protection against indirect contact by automatic disconnection of supply.....	16
531.1 Overcurrent protective devices.....	16
531.1.1 TN systems.....	16
531.1.2 TT systems.....	16
531.1.3 IT systems.....	16
531.2 Residual current protective devices.....	16
531.2.1 General conditions of installation.....	16
531.2.2 Selection of devices according to their method of application.....	16
531.2.3 TN systems.....	16
531.2.4 TT systems.....	16
531.2.5 IT systems.....	16
531.3 Insulation monitoring devices.....	16
531 Equipment for protection against electric shock.....	17
531.1 General.....	17
531.2 Devices for automatic disconnection of supply.....	18
531.2.1 General.....	18
531.2.2 Overcurrent protective devices.....	18
531.2.3 Residual current protective devices.....	20
531.3 Equipment for protection by double or reinforced insulation.....	23
531.3.1 General.....	23
531.4 Equipment for protection by electrical separation.....	25
531.5 Equipment for protection by extra-low-voltage provided by SELV and PELV systems.....	25
531.5.1 Sources for SELV or PELV systems.....	25
531.5.2 Selection of plugs and socket-outlets.....	25
531.6 Devices for additional protection.....	25
531.7 Monitoring devices.....	26
532 Devices and precautions for protection against thermal effects.....	26
532.1 General.....	26
532.2 Locations with a particular risk of fire.....	26
532.2.1 General.....	26
532.2.2 Locations with external influences BD2, BD3 or BD4.....	26
532.2.3 Locations with external influences BE2.....	27
532.2.3.1 General.....	27
532.2.3.2 Selection of residual current protective devices (RCD).....	27
532.2.3.3 Selection of residual current monitoring device (RCM) in IT systems.....	27
532.2.3.4 Selection of insulation monitoring devices (IMDs) in IT systems.....	27
532.3 Selection of arc fault detection devices (AFDD).....	27
533 Devices for protection against overcurrent.....	28
533.1 General requirements.....	28

533.1.1	General	28
533.1.2	Compliance with standards	28
533.1.2.1	General	28
533.1.2.2	Applicability of devices	28
533.1.3	Fuses	29
533.2	Selection of devices for protection against overload current	29
533.2.1	General	29
533.2.2	Presence of harmonic currents	30
533.2.3	Unequal current sharing between parallel conductors	30
533.3	Selection of devices for protection against short-circuit current	30
533.3.1	Thermal stresses	30
533.3.1.1	Cables and insulated conductors	30
533.3.1.2	Busbar trunking systems and powertracks	30
533.3.2	Breaking capacity	31
533.4	Positioning of overcurrent protection devices	31
533.4.1	General	31
533.4.2	Positioning of devices for overload protection	31
533.4.3	Positioning of devices for short-circuit protection	32
533.5	Co-ordination of overload and short-circuit protective functions	33
533.5.1	Protective functions provided by one device	33
533.5.2	Protective functions provided by separate devices	33
534	Devices for protection against transient overvoltages	33
534.1	General	33
534.2	Void	34
534.3	Void	34
534.4	Selection and erection of SPDs	34
534.4.1	SPD location and SPD test class	34
534.4.2	Transient overvoltage protection requirements	35
534.4.3	Connection types	35
534.4.4	Selection of SPDs	37
534.4.5	Protection of the SPD against overcurrent	42
534.4.6	Fault protection	44
534.4.7	SPDs installation in conjunction with RCDs	45
534.4.8	Connections of the SPD	45
534.4.9	Effective protective distance of SPDs	47
534.4.10	Connecting conductors of SPDs	48
535	Co-ordination of protective devices	48
535.1	Selectivity between overcurrent protective devices	48
535.1.1	General	48
535.1.2	Partial selectivity	49
535.1.3	Full selectivity	49
535.1.4	Total selectivity	49
535.1.5	Enhanced selectivity	49
535.2	Co-ordination between residual current protective devices and OCPDs	50
535.3	Selectivity between residual current protective devices	50
535.4	Selectivity of RCD and OCPD	50
535.5	Combined short-circuit protection of OCPDs	50
536	Isolation and switching	51
536.2	Isolation	51

536.2.1	General	51
536.2.2	Devices for isolation	52
536.3	Switching-off for mechanical maintenance	53
536.3.1	General	53
536.3.2	Devices for switching-off for mechanical maintenance	53
536.4	Emergency switching	54
536.4.1	General	54
536.4.2	Devices for emergency switching-off.....	54
536.4.3	Devices for emergency stopping	55
536.5	Functional switching (control).....	55
536.5.1	General	55
536.5.2	Devices for functional switching.....	55
537	Monitoring	56
537.1	General.....	56
537.1.1	Monitoring devices.....	56
537.1.2	Selection of insulation monitoring devices (IMDs)	56
537.1.3	Selection of residual current monitoring devices (RCMs)	56
537.2	IT systems for continuity of supply	56
537.2.1	General	56
537.2.2	Insulation monitoring devices (IMDs)	57
537.2.3	Installation of IMDs.....	57
537.3	IT public distribution system.....	57
537.4	Off-line systems in TN, TT and IT systems.....	57
Annex A (informative)	Position of devices for overload protection	59
A.1	General.....	59
A.2	Cases where overload protection need not be placed at the origin of the branch circuit	59
Annex B (informative)	Position of devices for short-circuit protection	61
B.1	General.....	61
B.2	Cases where short-circuit protection need not be placed at the origin of branch circuit	61
Annex C (informative)	SPD installation – Examples of installation diagrams according to system configurations	63
C.1	TT system – 3 phase supply plus neutral	63
C.2	TN-C and TN-C-S systems – 3 phase supply	67
C.3	TN-S system – 3 phase supply plus neutral.....	71
C.4	IT system – 3 phase supply with or without neutral	73
Annex D (informative)	Installation supplied by overhead lines	76
Annex E (normative)	Reference standards for devices for isolation and switching	77
Annex F (informative)	List of notes concerning certain countries	79
Annex G (informative)	Description of the different types of residual current devices (RCDs)	88
G.1	Description of RCD types	88
G.2	Examples of use of RCD types.....	89
Annex H (informative)	Additional information for the application of DC SPDs	92
H.1	General.....	92
H.2	Parameters for the selection of SPDs in DC applications	92
Bibliography	93

Figure 1 – Example of installation of class I, class II and class III tested SPDs	35
Figure 2 – Connection type CT1 (4+0-configuration) for a three-phase system with neutral	36
Figure 3 – Connection type CT1 (3+0-configuration) for a three-phase system.....	36
Figure 4 – Connection type CT2 (e.g. 3+1-configuration) for a three-phase system with neutral	37
Figure 5 – Connection points of an SPD assembly	42
Figure 6 – Example of overcurrent protection in the SPD branch by using a dedicated external overcurrent protective device.....	43
Figure 7 – Protective device, which is a part of the installation, also used to protect the SPD	44
Figure 8 – Connection of the SPD	46
Figure 9 – Example of installation of an SPD in order to decrease lead length of SPD supply conductors.....	47
Figure 10 – Example of selectivity.....	49
Figure 11 – Example of currents and their correlation to selectivity	50
Figure 12 – Example of combined short-circuit protection of OCPDs	51
Figure A.1 – Overload protective device (P_2) not at the origin of branch circuit (B)	59
Figure A.2 – Overload protective device (P_2) installed within 3 m of the origin of the branch circuit (B)	60
Figure B.1 – Limited change of position of short-circuit protective device (P_2) on a branch circuit.....	61
Figure B.2 – Short-circuit protective device P_2 installed at a point on the supply side of the origin of a branch circuit.....	62
Figure C.1 – Example of SPDA installation with connexion type CT2 on the supply side (upstream) of the main RCD in TT system.....	63
Figure C.2 – Example of SPD installation with connexion type CT2 on the supply side (upstream) of the main RCD in TT system.....	64
Figure C.3 – Example of SPDA installation on the load side (downstream) of the main RCD in TT system.....	65
Figure C.4 – Example of SPD installation on the load side (downstream) of the RCD in TT system.....	66
Figure C.5 – Example of SPDA installation in TN-C system	67
Figure C.6 – Example of SPD installation with connexion type CT1 in TN-C system.....	68
Figure C.7 – Example of SPD installation in TN-C-S system where the PEN is separated into PE and N at the origin of the installation (upstream of the SPD)	69
Figure C.8 – Example of SPDs installation in TN-C-S in different distribution boards	70
Figure C.9 – Example of SPDA installation in TN-S system.....	71
Figure C.10 – Example of SPDs installation in TN-S	72
Figure C.11 – Example of SPDA installation in IT system with neutral.....	73
Figure C.12 – Example of SPD installation in IT system without neutral	74
Figure C.13 – Example of SPD installation in IT system with neutral	75
Figure F.1 – Single user.....	84
Figure F.2 – Several users.....	84
Figure F.3 – Lamp control circuit with switching in the neutral conductor	86
Figure G.1 – Possible earth fault currents in systems with semiconductors	91

~~Table 1 – Required rated impulse voltage of equipment.....~~

Table 2 – U_c of the SPD dependent on supply system configuration 40

Table 3 – Nominal discharge current (I_n) in kA depending on supply system and connection type 41

Table 4 – Selection of impulse discharge current (I_{imp}) where the building is protected against direct lightning strike 41

Table 5 – Connection of the SPD dependent on supply system 45

Table D.1 – Selection of impulse discharge current (I_{imp}) 76

Table E.1 – Devices for isolation and switching..... 77

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 5-53: Selection and erection of electrical equipment – Devices for protection for safety, isolation, switching, control and monitoring

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 60364-5-53 edition 4.2 contains the fourth edition (2019-02) [documents 64/2352/FDIS and 64/2359/RVD], its amendment 1 (2020-12) [documents 64/2457/FDIS and 64/2465/RVD] and its amendment 2 (2024-12) [documents 64/2648/FDIS and 64/2738/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60364 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This fourth edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) revision of all clauses except 531 and 534;
- b) introduction of a new Clause 537 Monitoring;
- c) Clause 530 contains all normative references and all terms and definitions.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex F lists all of the “in-some-country” clauses on differing practices relating to the subject of this standard.

A list of all parts in the IEC 60364 series, published under the general title *Low-voltage electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendments will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The ‘colour inside’ logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 5-53: Selection and erection of electrical equipment – Devices for protection for safety, isolation, switching, control and monitoring

530.1 Scope

This document provides requirements for:

- a) isolation, switching, control and monitoring, and
- b) selection and erection of:
 - 1) devices for isolation, switching, control and monitoring, and
 - 2) devices to achieve compliance with measures of protection for safety.

530.2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60204-1, *Safety of machinery – Electrical equipment of machines – Part 1: General requirements*

IEC 60269-2, *Low-voltage fuses – Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K*

IEC 60269-3, *Low-voltage fuses – Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications) – Examples of standardized systems of fuses A to F*

IEC 60269-4, *Low-voltage fuses – Part 4: Supplementary requirements for use-links for the protection of semiconductor devices*

IEC 60309 (all parts), *Plugs, socket-outlets and couplers for industrial purposes*

IEC 60364 (all parts), *Low-voltage electrical installations*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*
IEC 60364-4-41:2005/AMD1:2017

IEC 60364-4-42:2010, *Low-voltage electrical installations – Part 4-42: Protection for safety – Protection against thermal effects*
IEC 60364-4-42:2010/AMD1:2014

IEC 60364-4-43:2008, *Low-voltage electrical installations – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 60364-4-44:2007, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*
IEC 60364-4-44:2007/AMD1:2015

IEC 60364-5-55, *Electrical installations of buildings – Part 5-55: Selection and erection of electrical equipment – Other equipment*

IEC 60364-6:2016, *Low voltage electrical installations– Part 6: Verification*

IEC 60417 (all parts), *Graphical symbols for use on equipment*

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60669-1, *Switches for household and similar fixed-electrical installations – Part 1: General requirements*

IEC 60669-2-1, *Switches for household and similar fixed electrical installations – Part 2-1: Particular requirements – Electronic switches*

IEC 60669-2-2, *Switches for household and similar fixed electrical installations – Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)*

IEC 60669-2-3, *Switches for household and similar fixed electrical installations – Part 2-3: Particular requirements – Time-delay switches (TDS)*

IEC 60669-2-4, *Switches for household and similar fixed electrical installations – Part 2-4: Particular requirements – Isolating switches*

IEC 60669-2-5, *Switches for household and similar fixed electrical installations – Part 2-5: Particular requirements – Switches and related accessories for use in home and building electronic systems (HBES)*

IEC 60669-2-6, *Switches for household and similar fixed electrical installations – Part 2-6: Particular requirements – Fireman's switches for exterior and interior signs and luminaires*

IEC 60670-24, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 24: Particular requirements for enclosures for housing protective devices and other power dissipating electrical equipment*

IEC 60884 (all parts), *Plugs and socket-outlets for household and similar purposes*

IEC 60898 (all parts), *Electrical accessories – Circuit-breakers for overcurrent protection for household and similar installations*

IEC 60906 (all parts), *IEC system of plugs and socket-outlets for household and similar purposes*

IEC 60947-2:2016, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 60947-3, *Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*

IEC 60947-4-1, *Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters*

IEC 60947-4-2, *Low-voltage switchgear and controlgear – Part 4-2: Contactors and motor-starters – AC semiconductor motor controllers and starters*

IEC 60947-4-3, *Low-voltage switchgear and controlgear – Part 4-3: Contactors and motor-starters – AC semiconductor controllers and contactors for non-motor loads*

IEC 60947-5-1, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 60947-6-1, *Low-voltage switchgear and controlgear – Part 6-1: Multiple function equipment – Transfer switching equipment*

IEC 60947-6-2, *Low-voltage switchgear and controlgear – Part 6-2: Multiple function equipment – Control and protective switching devices (or equipment) (CPS)*

IEC 61008 (all parts), *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)*

IEC 61009 (all parts), *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)*

IEC 61095, *Electromechanical contactors for household and similar purposes*

IEC 61439-2, *Low-voltage switchgear and controlgear assemblies – Part 2: Power switchgear and controlgear assemblies*

IEC 61439-3, *Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)*

IEC 61439-6, *Low-voltage switchgear and controlgear assemblies – Part 6: Busbar trunking systems (busways)*

IEC 61534 (all parts), *Powertrack systems*

IEC 61557-8, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 8: Insulation monitoring devices for IT systems*

IEC 61557-9, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 9: Equipment for insulation fault location in IT systems*

IEC 61643-11, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems – Requirements and test methods*

IEC 61643-12, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles*

IEC 61984:2008, *Connectors – Safety requirements and tests*

IEC 61995 (all parts), *Devices for the connection of luminaires for household and similar purposes*

IEC 62020, *Electrical accessories – Residual current monitors for household and similar uses (RCMs)*

IEC 62208, *Empty enclosures for low-voltage switchgear and controlgear assemblies – General requirements*

IEC 62305 (all parts), *Protection against lightning*

IEC 62423, *Type F and type B residual current operated circuit-breakers with and without integral overcurrent protection for household and similar uses*

IEC 62606, *General requirements for arc fault detection devices*

IEC 62626-1, *Low-voltage switchgear and controlgear enclosed equipment – Part 1: Enclosed switch-disconnectors outside the scope of IEC 60947-3 to provide isolation during repair and maintenance work*

CONTENTS

FOREWORD.....	6
530.1 Scope	8
530.2 Normative references.....	8
530.3 Terms and definitions.....	11
530.4 General and common requirements.....	14
530.5 Erection of equipment.....	14
531 Equipment for protection against electric shock	14
531.1 General.....	14
531.2 Devices for automatic disconnection of supply	15
531.2.1 General	15
531.2.2 Overcurrent protective devices	15
531.2.3 Residual current protective devices	17
531.3 Equipment for protection by double or reinforced insulation	20
531.3.1 General	20
531.4 Equipment for protection by electrical separation	22
531.5 Equipment for protection by extra-low-voltage provided by SELV and PELV systems	22
531.5.1 Sources for SELV or PELV systems.....	22
531.5.2 Selection of plugs and socket-outlets.....	22
531.6 Devices for additional protection	22
531.7 Monitoring devices.....	23
532 Devices and precautions for protection against thermal effects.....	23
532.1 General.....	23
532.2 Locations with a particular risk of fire	23
532.2.1 General	23
532.2.2 Locations with external influences BD2, BD3 or BD4	23
532.2.3 Locations with external influences BE2.....	24
532.2.3.1 General	24
532.2.3.2 Selection of residual current protective devices (RCD)	24
532.2.3.3 Selection of residual current monitoring device (RCM) in IT systems	24
532.2.3.4 Selection of insulation monitoring devices (IMDs) in IT systems	24
532.3 Selection of arc fault detection devices (AFDD)	24
533 Devices for protection against overcurrent.....	25
533.1 General requirements	25
533.1.1 General	25
533.1.2 Compliance with standards.....	25
533.1.2.1 General	25
533.1.2.2 Applicability of devices	25
533.1.3 Fuses	26
533.2 Selection of devices for protection against overload current.....	26
533.2.1 General	26
533.2.2 Presence of harmonic currents	27
533.2.3 Unequal current sharing between parallel conductors	27
533.3 Selection of devices for protection against short-circuit current.....	27
533.3.1 Thermal stresses	27
533.3.1.1 Cables and insulated conductors	27
533.3.1.2 Busbar trunking systems and powertracks	27

533.3.2	Breaking capacity	28
533.4	Positioning of overcurrent protection devices	28
533.4.1	General	28
533.4.2	Positioning of devices for overload protection	28
533.4.3	Positioning of devices for short-circuit protection	29
533.5	Co-ordination of overload and short-circuit protective functions.....	30
533.5.1	Protective functions provided by one device	30
533.5.2	Protective functions provided by separate devices.....	30
534	Devices for protection against transient overvoltages	30
534.1	General.....	30
534.2	Void.....	30
534.3	Void.....	30
534.4	Selection and erection of SPDs.....	30
534.4.1	SPD location and SPD test class	30
534.4.2	Transient overvoltage protection requirements	32
534.4.3	Connection types.....	32
534.4.4	Selection of SPDs.....	34
534.4.5	Protection of the SPD against overcurrent	38
534.4.6	Fault protection	40
534.4.7	SPDs installation in conjunction with RCDs.....	41
534.4.8	Connections of the SPD.....	41
534.4.9	Effective protective distance of SPDs	43
534.4.10	Connecting conductors of SPDs	44
535	Co-ordination of protective devices.....	44
535.1	Selectivity between overcurrent protective devices	44
535.1.1	General	44
535.1.2	Partial selectivity	45
535.1.3	Full selectivity.....	45
535.1.4	Total selectivity.....	45
535.1.5	Enhanced selectivity	45
535.2	Co-ordination between residual current protective devices and OCPDs.....	46
535.3	Selectivity between residual current protective devices	46
535.4	Selectivity of RCD and OCPD	46
535.5	Combined short-circuit protection of OCPDs	46
536	Isolation and switching	47
536.2	Isolation.....	47
536.2.1	General	47
536.2.2	Devices for isolation	48
536.3	Switching-off for mechanical maintenance	49
536.3.1	General	49
536.3.2	Devices for switching-off for mechanical maintenance	49
536.4	Emergency switching	50
536.4.1	General	50
536.4.2	Devices for emergency switching-off.....	50
536.4.3	Devices for emergency stopping	51
536.5	Functional switching (control).....	51
536.5.1	General	51
536.5.2	Devices for functional switching.....	51
537	Monitoring	52

537.1	General.....	52
537.1.1	Monitoring devices.....	52
537.1.2	Selection of insulation monitoring devices (IMDs).....	52
537.1.3	Selection of residual current monitoring devices (RCMs).....	52
537.2	IT systems for continuity of supply.....	52
537.2.1	General.....	52
537.2.2	Insulation monitoring devices (IMDs).....	53
537.2.3	Installation of IMDs.....	53
537.3	IT public distribution system.....	53
537.4	Off-line systems in TN, TT and IT systems.....	53
Annex A	(informative) Position of devices for overload protection.....	55
A.1	General.....	55
A.2	Cases where overload protection need not be placed at the origin of the branch circuit.....	55
Annex B	(informative) Position of devices for short-circuit protection.....	57
B.1	General.....	57
B.2	Cases where short-circuit protection need not be placed at the origin of branch circuit.....	57
Annex C	(informative) SPD installation – Examples of installation diagrams according to system configurations.....	59
C.1	TT system – 3 phase supply plus neutral.....	59
C.2	TN-C and TN-C-S systems – 3 phase supply.....	63
C.3	TN-S system – 3 phase supply plus neutral.....	67
C.4	IT system – 3 phase supply with or without neutral.....	69
Annex D	(informative) Installation supplied by overhead lines.....	72
Annex E	(normative) Reference standards for devices for isolation and switching.....	73
Annex F	(informative) List of notes concerning certain countries.....	75
Annex G	(informative) Description of the different types of residual current devices (RCDs).....	84
G.1	Description of RCD types.....	84
G.2	Examples of use of RCD types.....	85
Annex H	(informative) Additional information for the application of DC SPDs.....	88
H.1	General.....	88
H.2	Parameters for the selection of SPDs in DC applications.....	88
Bibliography	89
Figure 1	– Example of installation of class I, class II and class III tested SPDs.....	32
Figure 2	– Connection type CT1 (4+0-configuration) for a three-phase system with neutral.....	33
Figure 3	– Connection type CT1 (3+0-configuration) for a three-phase system.....	33
Figure 4	– Connection type CT2 (e.g. 3+1-configuration) for a three-phase system with neutral.....	34
Figure 5	– Connection points of an SPD assembly.....	38
Figure 6	– Example of overcurrent protection in the SPD branch by using a dedicated external overcurrent protective device.....	39
Figure 7	– Protective device, which is a part of the installation, also used to protect the SPD.....	40
Figure 8	– Connection of the SPD.....	42

Figure 9 – Example of installation of an SPD in order to decrease lead length of SPD supply conductors	43
Figure 10 – Example of selectivity	45
Figure 11 – Example of currents and their correlation to selectivity	46
Figure 12 – Example of combined short-circuit protection of OCPDs	47
Figure A.1 – Overload protective device (P_2) not at the origin of branch circuit (B)	55
Figure A.2 – Overload protective device (P_2) installed within 3 m of the origin of the branch circuit (B)	56
Figure B.1 – Limited change of position of short-circuit protective device (P_2) on a branch circuit	57
Figure B.2 – Short-circuit protective device P_2 installed at a point on the supply side of the origin of a branch circuit	58
Figure C.1 – Example of SPDA installation with connexion type CT2 on the supply side (upstream) of the main RCD in TT system	59
Figure C.2 – Example of SPD installation with connexion type CT2 on the supply side (upstream) of the main RCD in TT system	60
Figure C.3 – Example of SPDA installation on the load side (downstream) of the main RCD in TT system	61
Figure C.4 – Example of SPD installation on the load side (downstream) of the RCD in TT system	62
Figure C.5 – Example of SPDA installation in TN-C system	63
Figure C.6 – Example of SPD installation with connexion type CT1 in TN-C system	64
Figure C.7 – Example of SPD installation in TN-C-S system where the PEN is separated into PE and N at the origin of the installation (upstream of the SPD)	65
Figure C.8 – Example of SPDs installation in TN-C-S in different distribution boards	66
Figure C.9 – Example of SPDA installation in TN-S system	67
Figure C.10 – Example of SPDs installation in TN-S	68
Figure C.11 – Example of SPDA installation in IT system with neutral	69
Figure C.12 – Example of SPD installation in IT system without neutral	70
Figure C.13 – Example of SPD installation in IT system with neutral	71
Figure F.1 – Single user	80
Figure F.2 – Several users	80
Figure F.3 – Lamp control circuit with switching in the neutral conductor	82
Figure G.1 – Possible earth fault currents in systems with semiconductors	87
Table 2 – U_c of the SPD dependent on supply system configuration	36
Table 3 – Nominal discharge current (I_n) in kA depending on supply system and connection type	37
Table 4 – Selection of impulse discharge current (I_{imp}) where the building is protected against direct lightning strike	37
Table 5 – Connection of the SPD dependent on supply system	41
Table D.1 – Selection of impulse discharge current (I_{imp})	72
Table E.1 – Devices for isolation and switching	73

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –**Part 5-53: Selection and erection of electrical equipment – Devices for protection for safety, isolation, switching, control and monitoring****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 60364-5-53 edition 4.2 contains the fourth edition (2019-02) [documents 64/2352/FDIS and 64/2359/RVD], its amendment 1 (2020-12) [documents 64/2457/FDIS and 64/2465/RVD] and its amendment 2 (2024-12) [documents 64/2648/FDIS and 64/2738/RVD].

This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 60364 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This fourth edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) revision of all clauses except 531 and 534;
- b) introduction of a new Clause 537 Monitoring;
- c) Clause 530 contains all normative references and all terms and definitions.

This document has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex F lists all of the “in-some-country” clauses on differing practices relating to the subject of this standard.

A list of all parts in the IEC 60364 series, published under the general title *Low-voltage electrical installations*, can be found on the IEC website.

The committee has decided that the contents of this document and its amendments will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The ‘colour inside’ logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 5-53: Selection and erection of electrical equipment – Devices for protection for safety, isolation, switching, control and monitoring

530.1 Scope

This document provides requirements for:

- a) isolation, switching, control and monitoring, and
- b) selection and erection of:
 - 1) devices for isolation, switching, control and monitoring, and
 - 2) devices to achieve compliance with measures of protection for safety.

530.2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60204-1, *Safety of machinery – Electrical equipment of machines – Part 1: General requirements*

IEC 60269-2, *Low-voltage fuses – Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to K*

IEC 60269-3, *Low-voltage fuses – Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household and similar applications) – Examples of standardized systems of fuses A to F*

IEC 60269-4, *Low-voltage fuses – Part 4: Supplementary requirements for use-links for the protection of semiconductor devices*

IEC 60309 (all parts), *Plugs, socket-outlets and couplers for industrial purposes*

IEC 60364 (all parts), *Low-voltage electrical installations*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*
IEC 60364-4-41:2005/AMD1:2017

IEC 60364-4-42:2010, *Low-voltage electrical installations – Part 4-42: Protection for safety – Protection against thermal effects*
IEC 60364-4-42:2010/AMD1:2014

IEC 60364-4-43:2008, *Low-voltage electrical installations – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 60364-4-44:2007, *Low-voltage electrical installations – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*
IEC 60364-4-44:2007/AMD1:2015

IEC 60364-5-55, *Electrical installations of buildings – Part 5-55: Selection and erection of electrical equipment – Other equipment*

IEC 60364-6:2016, *Low voltage electrical installations– Part 6: Verification*

IEC 60417 (all parts), *Graphical symbols for use on equipment*

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60669-1, *Switches for household and similar fixed-electrical installations – Part 1: General requirements*

IEC 60669-2-1, *Switches for household and similar fixed electrical installations – Part 2-1: Particular requirements – Electronic switches*

IEC 60669-2-2, *Switches for household and similar fixed electrical installations – Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)*

IEC 60669-2-3, *Switches for household and similar fixed electrical installations – Part 2-3: Particular requirements – Time-delay switches (TDS)*

IEC 60669-2-4, *Switches for household and similar fixed electrical installations – Part 2-4: Particular requirements – Isolating switches*

IEC 60669-2-5, *Switches for household and similar fixed electrical installations – Part 2-5: Particular requirements – Switches and related accessories for use in home and building electronic systems (HBES)*

IEC 60669-2-6, *Switches for household and similar fixed electrical installations – Part 2-6: Particular requirements – Fireman's switches for exterior and interior signs and luminaires*

IEC 60670-24, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 24: Particular requirements for enclosures for housing protective devices and other power dissipating electrical equipment*

IEC 60884 (all parts), *Plugs and socket-outlets for household and similar purposes*

IEC 60898 (all parts), *Electrical accessories – Circuit-breakers for overcurrent protection for household and similar installations*

IEC 60906 (all parts), *IEC system of plugs and socket-outlets for household and similar purposes*

IEC 60947-2:2016, *Low-voltage switchgear and controlgear – Part 2: Circuit-breakers*

IEC 60947-3, *Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units*

IEC 60947-4-1, *Low-voltage switchgear and controlgear – Part 4-1: Contactors and motor-starters – Electromechanical contactors and motor-starters*

IEC 60947-4-2, *Low-voltage switchgear and controlgear – Part 4-2: Contactors and motor-starters – AC semiconductor motor controllers and starters*

IEC 60947-4-3, *Low-voltage switchgear and controlgear – Part 4-3: Contactors and motor-starters – AC semiconductor controllers and contactors for non-motor loads*

IEC 60947-5-1, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 60947-6-1, *Low-voltage switchgear and controlgear – Part 6-1: Multiple function equipment – Transfer switching equipment*

IEC 60947-6-2, *Low-voltage switchgear and controlgear – Part 6-2: Multiple function equipment – Control and protective switching devices (or equipment) (CPS)*

IEC 61008 (all parts), *Residual current operated circuit-breakers without integral overcurrent protection for household and similar uses (RCCBs)*

IEC 61009 (all parts), *Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)*

IEC 61095, *Electromechanical contactors for household and similar purposes*

IEC 61439-2, *Low-voltage switchgear and controlgear assemblies – Part 2: Power switchgear and controlgear assemblies*

IEC 61439-3, *Low-voltage switchgear and controlgear assemblies – Part 3: Distribution boards intended to be operated by ordinary persons (DBO)*

IEC 61439-6, *Low-voltage switchgear and controlgear assemblies – Part 6: Busbar trunking systems (busways)*

IEC 61534 (all parts), *Powertrack systems*

IEC 61557-8, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 8: Insulation monitoring devices for IT systems*

IEC 61557-9, *Electrical safety in low voltage distribution systems up to 1 000 V a.c. and 1 500 V d.c. – Equipment for testing, measuring or monitoring of protective measures – Part 9: Equipment for insulation fault location in IT systems*

IEC 61643-11, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems – Requirements and test methods*

IEC 61643-12, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles*

IEC 61984:2008, *Connectors – Safety requirements and tests*

IEC 61995 (all parts), *Devices for the connection of luminaires for household and similar purposes*

IEC 62020, *Electrical accessories – Residual current monitors for household and similar uses (RCMs)*

IEC 62208, *Empty enclosures for low-voltage switchgear and controlgear assemblies – General requirements*

IEC 62305 (all parts), *Protection against lightning*

IEC 62423, *Type F and type B residual current operated circuit-breakers with and without integral overcurrent protection for household and similar uses*

IEC 62606, *General requirements for arc fault detection devices*

IEC 62626-1, *Low-voltage switchgear and controlgear enclosed equipment – Part 1: Enclosed switch-disconnectors outside the scope of IEC 60947-3 to provide isolation during repair and maintenance work*