



IEEE

IEC/IEEE 62395-2

Edition 1.0 2024-06

INTERNATIONAL STANDARD



**Electrical resistance trace heating systems for industrial and commercial applications –
Part 2: Application guide for system design, installation and maintenance**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 25.180.10

ISBN 978-2-8322-8826-9

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

| | |
|---|----|
| FOREWORD..... | 7 |
| INTRODUCTION..... | 9 |
| 1 Scope..... | 10 |
| 2 Normative references | 11 |
| 3 Terms and definitions | 11 |
| 4 Surface heating of vessels and piping systems | 11 |
| 4.1 Application description | 11 |
| 4.1.1 General | 11 |
| 4.1.2 Environmental conditions..... | 11 |
| 4.1.3 Trace heating systems considerations | 12 |
| 4.2 Design information – General..... | 12 |
| 4.2.1 General | 12 |
| 4.2.2 Electrical system design | 12 |
| 4.2.3 Control and monitoring | 13 |
| 4.2.4 Trace heating system design | 14 |
| 4.2.5 Design information documentation | 14 |
| 4.3 Thermal system design | 14 |
| 4.3.1 General | 14 |
| 4.3.2 Design conditions | 15 |
| 4.3.3 Thermal insulation | 15 |
| 4.3.4 Heat loss determination | 19 |
| 4.3.5 Design safety factor..... | 21 |
| 4.3.6 Heat-up considerations | 21 |
| 4.3.7 Selection of trace heater..... | 22 |
| 4.3.8 Design calculations..... | 25 |
| 4.3.9 Theoretical sheath temperature calculations – Metallic pipe applications | 25 |
| 4.3.10 Theoretical sheath temperature calculations – Non-metallic pipe applications | 26 |
| 4.3.11 Design documentation | 27 |
| 4.3.12 Start-up at low ambient temperatures | 28 |
| 4.3.13 Long trace heater circuits | 28 |
| 4.3.14 Chimney effect..... | 28 |
| 4.4 Electrical design | 28 |
| 4.5 Control and monitoring system design..... | 29 |
| 4.5.1 General | 29 |
| 4.5.2 Mechanical temperature controllers | 29 |
| 4.5.3 Electronic temperature controllers | 29 |
| 4.5.4 Application suitability | 30 |
| 4.5.5 Location of controllers | 31 |
| 4.5.6 Location of sensors | 31 |
| 4.5.7 Alarm considerations | 32 |
| 4.5.8 Integrated control | 33 |
| 4.5.9 Flow pattern analysis..... | 33 |
| 4.5.10 Dead-leg control technique | 35 |
| 4.5.11 Monitoring requirements for fire sprinkler systems | 35 |
| 4.6 Special design considerations..... | 35 |
| 4.6.1 General | 35 |

| | | |
|--------|--|----|
| 4.6.2 | Freeze protection systems | 35 |
| 4.6.3 | Sprinkler systems, fire suppression..... | 36 |
| 4.6.4 | Hot water services/tempered water | 37 |
| 4.6.5 | Safety shower design requirements | 38 |
| 4.6.6 | Specialty lines | 38 |
| 4.7 | Installation | 40 |
| 4.7.1 | General | 40 |
| 4.7.2 | Personnel aspects | 40 |
| 4.7.3 | Preparatory work | 41 |
| 4.7.4 | Preliminary installation of trace heating circuits | 41 |
| 4.7.5 | Pre-installation insulation resistance test | 41 |
| 4.7.6 | Installation of trace heater systems..... | 42 |
| 4.7.7 | Installation of control and monitoring equipment | 44 |
| 4.7.8 | Necessary modifications | 45 |
| 4.7.9 | Installation of the thermal insulation system..... | 45 |
| 4.7.10 | Installation of electrical power..... | 47 |
| 4.7.11 | Commissioning | 47 |
| 4.8 | Maintenance | 48 |
| 4.8.1 | General | 48 |
| 4.8.2 | Training of maintenance personnel | 49 |
| 4.8.3 | Frequency of inspection..... | 49 |
| 4.8.4 | Maintenance program documentation | 49 |
| 4.8.5 | Visual evaluation | 49 |
| 4.8.6 | Electrical evaluation..... | 50 |
| 4.8.7 | Review of the electrical protection system | 50 |
| 4.9 | Repair..... | 50 |
| 4.9.1 | General | 50 |
| 4.9.2 | Fault location..... | 50 |
| 4.9.3 | Practicability of repair to electric trace heaters | 51 |
| 4.9.4 | Repair techniques for electrical trace heaters | 51 |
| 5 | Roof and gutter deicing..... | 52 |
| 5.1 | Application description | 52 |
| 5.2 | Design information – General..... | 52 |
| 5.3 | Thermal design | 53 |
| 5.4 | Electrical design | 53 |
| 5.5 | Control and monitoring system design..... | 53 |
| 5.6 | Special design considerations | 54 |
| 5.7 | Installation | 54 |
| 5.7.1 | General | 54 |
| 5.7.2 | Trace heaters and component mounting | 54 |
| 5.8 | Maintenance | 57 |
| 5.9 | Repair..... | 57 |
| 6 | Rail heating | 57 |
| 6.1 | Application description | 57 |
| 6.1.1 | General | 57 |
| 6.1.2 | Switch point heating..... | 58 |
| 6.1.3 | Contact/live rail heating | 58 |
| 6.1.4 | Track heating..... | 58 |
| 6.1.5 | Catenary/pantograph shoe heating | 58 |

| | | |
|-------|---|----|
| 6.2 | Design information | 59 |
| 6.2.1 | General | 59 |
| 6.2.2 | Weather data | 59 |
| 6.2.3 | Rail system description | 59 |
| 6.2.4 | System design | 59 |
| 6.3 | Thermal design | 60 |
| 6.3.1 | Heating load determination | 60 |
| 6.3.2 | Typical heating load | 60 |
| 6.4 | Electrical design | 60 |
| 6.5 | Control and monitoring system design | 60 |
| 6.6 | Special design considerations | 61 |
| 6.6.1 | Electrical considerations | 61 |
| 6.6.2 | Finite element analysis | 61 |
| 6.7 | Installation | 61 |
| 6.7.1 | General | 61 |
| 6.7.2 | Point heating | 62 |
| 6.7.3 | Swing nose crossing | 62 |
| 6.7.4 | Clamp lock heating | 63 |
| 6.7.5 | Contact/live rail heating and track heating | 63 |
| 6.7.6 | Catenary/pantograph shoe heating | 64 |
| 6.8 | Maintenance | 64 |
| 6.9 | Repair | 64 |
| 7 | Snow melting | 64 |
| 7.1 | Application description | 64 |
| 7.2 | Design information | 65 |
| 7.2.1 | General | 65 |
| 7.2.2 | Weather data | 65 |
| 7.2.3 | Construction details of workpiece | 65 |
| 7.2.4 | Electrical considerations | 65 |
| 7.2.5 | System performance level | 65 |
| 7.2.6 | Trace heater layout and component mounting | 66 |
| 7.3 | Thermal design – Power output (heat load) determination | 69 |
| 7.4 | Electrical design | 70 |
| 7.5 | Control and monitoring system design | 70 |
| 7.6 | Special design considerations | 70 |
| 7.7 | Installation | 71 |
| 7.8 | Maintenance | 71 |
| 7.9 | Repair | 71 |
| 8 | Floor warming | 72 |
| 8.1 | Application description | 72 |
| 8.2 | Design information | 72 |
| 8.2.1 | General | 72 |
| 8.2.2 | Environmental data | 72 |
| 8.2.3 | Construction details of workpiece | 72 |
| 8.2.4 | Electrical considerations | 72 |
| 8.2.5 | Trace heater layout and component mounting | 72 |
| 8.3 | Thermal design – Heat load determination | 74 |
| 8.4 | Electrical design | 75 |
| 8.5 | Control and monitoring system design | 75 |

| | | |
|-----------------------|--|----|
| 8.6 | Special design consideration..... | 75 |
| 8.7 | Installation | 76 |
| 8.8 | Maintenance | 76 |
| 8.9 | Repair..... | 76 |
| 9 | Frost heave prevention | 76 |
| 9.1 | Application description | 76 |
| 9.2 | Design information | 77 |
| 9.2.1 | General | 77 |
| 9.2.2 | Construction details of the floor | 77 |
| 9.2.3 | Electrical considerations | 77 |
| 9.3 | Heat load determination | 77 |
| 9.3.1 | General | 77 |
| 9.3.2 | Trace heater layout and component mounting..... | 79 |
| 9.4 | Electrical design | 79 |
| 9.5 | Control and monitoring system design..... | 79 |
| 9.5.1 | Control options | 79 |
| 9.5.2 | Monitoring | 79 |
| 9.6 | Special design considerations | 79 |
| 9.7 | Installation | 80 |
| 9.8 | Maintenance | 80 |
| 9.9 | Repair..... | 80 |
| 10 | Underground thermal energy storage systems | 80 |
| 10.1 | Application description | 80 |
| 10.2 | Design information | 81 |
| 10.2.1 | General | 81 |
| 10.2.2 | Environmental data..... | 81 |
| 10.2.3 | Construction details of building | 81 |
| 10.2.4 | Electrical considerations | 81 |
| 10.2.5 | Trace heater layout and component mounting..... | 81 |
| 10.3 | Thermal design – Heat-loss determination | 82 |
| 10.4 | Electrical design | 82 |
| 10.5 | Control and monitoring system design..... | 82 |
| 10.6 | Special design considerations when trace heaters are located in sand layer | 83 |
| 10.7 | Installation | 83 |
| 10.7.1 | General | 83 |
| 10.7.2 | Installation in sand..... | 83 |
| 10.7.3 | Installation in concrete..... | 83 |
| 10.8 | Maintenance | 84 |
| 10.9 | Repair..... | 84 |
| Annex A (informative) | Pre-installation checks | 85 |
| Annex B (informative) | Trace heater commissioning record | 86 |
| Annex C (informative) | Maintenance schedule and log record | 87 |
| Bibliography | | 88 |
| Figure 1 | – Thermal insulation – Weather-barrier installation..... | 17 |
| Figure 2 | – Typical temperature profile..... | 19 |
| Figure 3 | – Equilibrium conditions for workpiece maintenance..... | 24 |

| | |
|---|----|
| Figure 4 – Equilibrium conditions for upper limit evaluation | 24 |
| Figure 5 – Heated tank example | 34 |
| Figure 6 – Bypass example | 34 |
| Figure 7 – Fire sprinkler sprig: tapered thermal insulation | 37 |
| Figure 8 – Double containment system | 39 |
| Figure 9 – Gravity flow piping systems | 40 |
| Figure 10 – Ice dam formation | 52 |
| Figure 11 – Downspout to underground drain | 53 |
| Figure 12 – Roof and gutter trace heater arrangement | 55 |
| Figure 13 – Gutter detail | 55 |
| Figure 14 – Typical roof mounting methods | 56 |
| Figure 15 – Drain detail for flat roof | 57 |
| Figure 16 – Typical positioning of point trace heater on stock rail and switch rail | 62 |
| Figure 17 – Typical positioning of trace heater on swing nose crossing | 62 |
| Figure 18 – Typical clamp lock trace heater | 63 |
| Figure 19 – Typical positioning of trace heater on steel and aluminium clad contact rails | 63 |
| Figure 20 – Typical positioning of trace heater in pantograph shoe | 64 |
| Figure 21 – Snow melting trace heater embedded in concrete | 67 |
| Figure 22 – Snow melting trace heater located in conduit | 68 |
| Figure 23 – Expansion joint detail | 69 |
| Figure 24 – Snow melting junction box location | 69 |
| Figure 25 – Typical floor warming trace heater mounting | 74 |
| Figure 26 – Typical floor heating power requirements | 75 |
| Figure 27 – Typical frost heave prevention substructure | 77 |
| Figure 28 – Frost heave prevention power requirements | 78 |
| Figure 29 – Typical underground thermal energy storage system installation | 82 |
| | |
| Table 1 – Trace heater and surface heater types and related attributes | 10 |
| Table 2 – Application types | 13 |
| Table 3 – Recommendations for monitoring and control – Type II and III control | 31 |
| Table 4 – Recommendations for hot water services and tempered water temperatures | 37 |
| Table 5 – Minimum values of Insulation resistance | 42 |
| Table 6 – Typical snow melting heat loads | 66 |

ELECTRICAL RESISTANCE TRACE HEATING SYSTEMS FOR INDUSTRIAL AND COMMERCIAL APPLICATIONS –

Part 2: Application guide for system design, installation and maintenance

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC document(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation.

IEEE Standards documents are developed within IEEE Societies and Standards Coordinating Committees of the IEEE Standards Association (IEEE SA) Standards Board. IEEE develops its standards through a consensus development process, approved by the American National Standards Institute, which brings together volunteers representing varied viewpoints and interests to achieve the final product. Volunteers are not necessarily members of IEEE and serve without compensation. While IEEE administers the process and establishes rules to promote fairness in the consensus development process, IEEE does not independently evaluate, test, or verify the accuracy of any of the information contained in its standards. Use of IEEE Standards documents is wholly voluntary. *IEEE documents are made available for use subject to important notices and legal disclaimers (see <https://standards.ieee.org/ipr/disclaimers.html> for more information).*

IEC collaborates closely with IEEE in accordance with conditions determined by agreement between the two organizations. This Dual Logo International Standard was jointly developed by the IEC and IEEE under the terms of that agreement.

- 2) The formal decisions of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees. The formal decisions of IEEE on technical matters, once consensus within IEEE Societies and Standards Coordinating Committees has been reached, is determined by a balanced ballot of materially interested parties who indicate interest in reviewing the proposed standard. Final approval of the IEEE standards document is given by the IEEE Standards Association (IEEE SA) Standards Board.
- 3) IEC/IEEE Publications have the form of recommendations for international use and are accepted by IEC National Committees/IEEE Societies in that sense. While all reasonable efforts are made to ensure that the technical content of IEC/IEEE Publications is accurate, IEC or IEEE cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications (including IEC/IEEE Publications) transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC/IEEE Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC and IEEE do not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC and IEEE are not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or IEEE or their directors, employees, servants or agents including individual experts and members of technical committees and IEC National Committees, or volunteers of IEEE Societies and the Standards Coordinating Committees of the IEEE Standards Association (IEEE SA) Standards Board, for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC/IEEE Publication or any other IEC or IEEE Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that implementation of this IEC/IEEE Publication may require use of material covered by patent rights. By publication of this standard, no position is taken with respect to the existence or validity of any patent rights in connection therewith. IEC or IEEE shall not be held responsible for identifying Essential Patent Claims for which a license may be required, for conducting inquiries into the legal validity or scope of Patent Claims or determining whether any licensing terms or conditions provided in connection with submission of a Letter of Assurance, if any, or in any licensing agreements are reasonable or non-discriminatory. Users of this standard are expressly advised that determination of the validity of any patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

IEC/IEEE 62395-2 was prepared by IEC technical committee 27: Industrial electroheating and electromagnetic, in cooperation with the Petroleum & Chemical Industry Committee of the IEEE Industrial Applications Society, under the IEC/IEEE Dual Logo Agreement between IEC and IEEE. It is an International Standard.

This document is published as an IEC/IEEE Dual Logo standard.

This standard cancels and replaces IEC 62395-2:2013. This edition constitutes a technical revision.

This standard includes the following significant technical changes with respect to IEC 62395-2:2013:

- a) Design considerations for trace heating on sprinkler systems have been expanded and a figure has been added to illustrate how to avoid undue shadowing of spray patterns from insulated sprigs close to sprinkler heads;
- b) Specific details of design considerations for trace heating for emergency eyewash units and safety showers have been added.

The text of this International Standard is based on the following IEC documents:

| | |
|--------------|------------------|
| Draft | Report on voting |
| 27/1183/FDIS | 27/1185/RVD |

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with the rules given in the ISO/IEC Directives, Part 2, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications/.

This standard is intended to be used in conjunction with IEC/IEEE 62395-1.

A list of all parts in the IEC 62395 series, under the general title *Electrical resistance trace heating systems for industrial and commercial applications*, can be found on the IEC website.

The IEC Technical Committee and IEEE Technical Committee have decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

IEC/IEEE 62395-1 provides the essential requirements and testing appropriate to electrical resistance trace heating equipment used in industrial and commercial applications. While some of this work already exists in national or international standards, this document has collated much of this existing work and added considerably to it.

IEC/IEEE 62395-2 provides detailed recommendations for the system design, installation, maintenance and repair of electrical resistance trace heating systems in industrial and commercial applications which can include piping, vessels, roofs and concrete slab heating applications.

It is the objective of the IEC/IEEE 62395 series that, when in normal use, electrical trace heating systems operate safely under their defined conditions of use, by

- a) employing heaters of the appropriate construction so as to meet the test criteria and requirements detailed in IEC/IEEE 62395-1. The construction includes a metallic sheath, braid, screen or equivalent electrically conductive covering;
- b) operating at safe temperatures when designed, installed, and maintained in accordance with IEC/IEEE 62395-2;
- c) having at least the minimum levels of overcurrent and earth-fault protection required in IEC/IEEE 62395-1 and IEC/IEEE 62395-2.

ELECTRICAL RESISTANCE TRACE HEATING SYSTEMS FOR INDUSTRIAL AND COMMERCIAL APPLICATIONS –

Part 2: Application guide for system design, installation and maintenance

1 Scope

This part of IEC/IEEE 62395 provides detailed recommendations for the system design, installation, maintenance and repair of electrical resistance trace heating systems in industrial and commercial applications. This document does not include or provide for any applications in potentially explosive atmospheres.

This document pertains to trace heating systems that can comprise either factory fabricated or field-assembled (work-site) units, and which can be series or parallel trace heaters, or surface heaters (heater pads or heater panels) that have been assembled and/or terminated in accordance with the manufacturer's instructions.

The products covered by this document are intended to be installed by persons who are suitably trained in the techniques required and that only trained personnel carry out especially critical work, such as the installation of connections and terminations. Installations are intended to be carried out under the supervision of a qualified person who has undergone supplementary training in electric trace heating systems.

This document does not cover induction, impedance or skin effect heating.

Trace heating systems and surface heating systems can be grouped into different types of installations. These are characterized by different requirements for testing and are usually certified for a specific type of installation or application. Typical applications for the different types of installation are shown in Table 1.

Table 1 – Trace heater and surface heater types and related attributes

| Trace heater type | Intended installations | Examples of installations | Required attributes |
|-------------------|--|--|--|
| A | Insulated surfaces (including pipe) | Hot water lines Freeze protection Grease lines Fuel oil lines Pre-insulated pipe Below grade trace heating Sprinkler systems | Dielectric, thermal, mechanical, moisture exclusion, and performance characteristics verification Sprinkler system verification (if specified for use) |
| B | Outdoor exposed areas | Roof deicing Gutter and downspouts deicing Catch basins and drains Rail heating systems | Dielectric, thermal, mechanical, moisture exclusion, and performance characteristics verification Increased moisture resistance UV and condensation resistance Resistance to cutting Abrasion resistance Tension test Rail system tests (if specified for use) |

| Trace heater type | Intended installations | Examples of installations | Required attributes |
|--|--|--|---|
| C | Installations with embedded trace heating | Embedded snow melting Embedded frost heave protection Embedded floor warming Embedded energy storage systems Embedded door frames | Dielectric, thermal, mechanical, moisture exclusion, and performance characteristics verification Resistance to cutting Resistance to crushing |
| D | Installations with trace heater inside conduit or piping | Embedded snow melting Embedded frost heave protection Embedded floor warming Embedded energy storage systems Embedded door frames Internal trace heating for freeze protection of potable water lines Enclosed drains and culverts | Dielectric, thermal, mechanical, moisture exclusion, and performance characteristics verification Increased moisture resistance (pressurized or non-pressurized) Pull-strength evaluation |
| NOTE Trace heating systems intended for use in explosive atmospheres are the subject of IEC/IEEE 60079-30-1 and IEC/IEEE 60079-30-2. | | | |

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/IEEE 62395-1:2024, *Electrical resistance trace heating systems for industrial and commercial applications – Part 1: General and testing requirements*