



TECHNICAL REPORT

Short-circuit currents – Calculation of effects – Part 2: Examples of calculation

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 17.220.01; 29.240.20

ISBN 978-2-8322-2551-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

| | |
|---|----|
| FOREWORD..... | 5 |
| 1 Scope..... | 7 |
| 2 Normative references..... | 7 |
| 3 Symbols and units..... | 7 |
| 4 Example 1 – Mechanical effects on a 10 kV arrangement with single rigid conductors..... | 8 |
| 4.1 General..... | 8 |
| 4.2 Data..... | 9 |
| 4.3 Normal load case: Conductor stress and forces on the supports caused by dead load..... | 9 |
| 4.4 Exceptional load case: Effects of short-circuit currents..... | 10 |
| 4.4.1 Maximum force on the central main conductor..... | 10 |
| 4.4.2 Conductor stress and forces on the supports..... | 11 |
| 4.5 Conclusions..... | 13 |
| 5 Example 2 – Mechanical effects on a 10 kV arrangement with multiple rigid conductors..... | 14 |
| 5.1 General..... | 14 |
| 5.2 Data (additional to the data of Example 1)..... | 14 |
| 5.3 Normal load case: Conductor stress and forces on the supports caused by dead load..... | 15 |
| 5.4 Exceptional load case: Effects of short-circuit currents..... | 15 |
| 5.4.1 Maximum forces on the conductors..... | 15 |
| 5.4.2 Conductor stress and forces on the supports..... | 16 |
| 5.5 Conclusions..... | 20 |
| 6 Example 3. – Mechanical effects on a high-voltage arrangement with rigid conductors..... | 20 |
| 6.1 General..... | 20 |
| 6.2 Data..... | 21 |
| 6.3 Normal load case: Conductor stress and forces on the supports caused by dead load..... | 22 |
| 6.4 Exceptional load case: Effects of short-circuit currents..... | 23 |
| 6.4.1 Maximum force on the central main conductor..... | 23 |
| 6.4.2 Conductor stress and forces on the supports..... | 23 |
| 6.4.3 Conclusions..... | 29 |
| 7 Example 4. – Mechanical effects on a 110 kV arrangement with slack conductors..... | 30 |
| 7.1 General..... | 30 |
| 7.2 Data..... | 31 |
| 7.3 Electromagnetic load and characteristic parameters..... | 32 |
| 7.4 Tensile force $F_{t,d}$ during short-circuit caused by swing out..... | 34 |
| 7.5 Dynamic conductor sag at midspan..... | 35 |
| 7.6 Tensile force $F_{f,d}$ after short-circuit caused by drop..... | 36 |
| 7.7 Horizontal span displacement b_h and minimum air clearance a_{min} | 36 |
| 7.8 Conclusions..... | 36 |
| 8 Example 5. – Mechanical effects on strained conductors..... | 37 |
| 8.1 General..... | 37 |
| 8.2 Common data..... | 37 |
| 8.3 Centre-line distance between sub-conductors $a_s = 0,1\text{ m}$ | 38 |

| | | |
|--------|--|----|
| 8.3.1 | Electromagnetic load and characteristic parameters | 38 |
| 8.3.2 | Tensile force $F_{t,d}$ during short-circuit caused by swing out | 41 |
| 8.3.3 | Dynamic conductor sag at midspan | 41 |
| 8.3.4 | Tensile force $F_{f,d}$ after short-circuit caused by drop | 42 |
| 8.3.5 | Horizontal span displacement b_h and minimum air clearance a_{min} | 43 |
| 8.3.6 | Pinch force $F_{pi,d}$ | 43 |
| 8.3.7 | Conclusions | 43 |
| 8.4 | Centre-line distance between sub-conductors $a_s = 0,4$ m | 44 |
| 8.4.1 | Preliminary remarks | 44 |
| 8.4.2 | Characteristic dimensions and parameters | 44 |
| 8.4.3 | Pinch force $F_{pi,d}$ | 45 |
| 8.4.4 | Conclusions | 47 |
| 9 | Example 6 – Mechanical effects on strained conductors with dropper in the middle of the span | 47 |
| 9.1 | General | 47 |
| 9.2 | Common data | 48 |
| 9.3 | Plane of the dropper parallel to the main conductors | 48 |
| 9.3.1 | General | 48 |
| 9.3.2 | Current flow along the whole length of the main conductor span | 49 |
| 9.3.3 | Current flow along half of the length of the main conductor and along the dropper | 57 |
| 9.4 | Plane of the dropper perpendicular to the main conductors | 64 |
| 9.4.1 | General | 64 |
| 9.4.2 | Current flow along the whole length of the main conductor span | 64 |
| 9.4.3 | Current flow along half of the length of the main conductor and along the dropper | 69 |
| 10 | Example 7 – Mechanical effects on vertical main conductors (droppers) | 77 |
| 10.1 | General | 77 |
| 10.2 | Data | 77 |
| 10.3 | Short-circuit tensile force and maximum horizontal displacement | 78 |
| 10.4 | Pinch force | 78 |
| 10.4.1 | Static tensile force regarding droppers | 78 |
| 10.4.2 | Characteristic dimensions and parameters | 79 |
| 10.4.3 | Pinch force $F_{pi,d}$ | 80 |
| 10.5 | Conclusions | 81 |
| 11 | Example 8 – Thermal effect on bare conductors | 81 |
| 11.1 | General | 81 |
| 11.2 | Data | 81 |
| 11.3 | Calculations | 82 |
| 11.4 | Conclusion | 82 |
| | Bibliography | 83 |
| | Figure 1 – Conductor arrangement | 8 |
| | Figure 2 – Position of the sub-conductors and connecting pieces | 14 |
| | Figure 3 – Two-span arrangement with tubular conductors | 21 |
| | Figure 4 – Arrangement with slack conductors | 31 |
| | Figure 5 – Arrangement with strained conductors | 37 |
| | Figure 6 – Arrangement with strained conductors and droppers in midspan. Plane of the droppers parallel to the main conductors | 47 |

Figure 7 – Possible arrangement of perpendicular droppers in three-phase system and two-line system 64

Figure 8 – Arrangement with strained conductors 77

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SHORT-CIRCUIT CURRENTS –
CALCULATION OF EFFECTS****Part 2: Examples of calculation**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC TR 60865-2, which is a technical report, has been prepared by IEC technical committee 73: Short-circuit currents.

This second edition cancels and replaces the first edition published in 1994. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition.

- a) The determinations for auto reclosure together with rigid conductors have been revised.

- b) The configurations in cases of flexible conductor arrangements have been changed.
- c) The influence of mid-span droppers to the span has been included.
- d) For vertical cable-connection the displacement and the tensile force onto the lower fixing point may be calculated now.
- e) Additional recommendations for foundation loads due to tensile forces have been added.
- f) The subclause for determination of the thermal equivalent short-circuits current has been deleted (is part of IEC 60909-0:2001 now).
- g) The standard IEC 60865-1:2011 has been reorganized and some of the symbols have been changed to follow the conceptual characteristic of international standards.

The text of this technical report is based on the following documents:

| | |
|---------------|------------------|
| Enquiry draft | Report on voting |
| 73/168/DTR | 73/173/RVC |

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts in the IEC 60865 series, published under the general title *Short-circuit currents – Calculations of effects*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

SHORT-CIRCUIT CURRENTS – CALCULATION OF EFFECTS

Part 2: Examples of calculation

1 Scope

The object of this part of IEC 60865, which is a Technical Report, is to show the application of procedures for the calculation of mechanical and thermal effects due to short circuits as presented in IEC 60865-1. Thus, this technical report is an addition to IEC 60865-1. It does not, however, change the basis for standardized procedures given in that publication.

The following points should particularly be noted:

- a) The examples in this Technical Report illustrate how to make the calculations according to IEC 60865-1 in a simplified and easy-to-follow manner. They are not intended as a check for computer programs.
- b) The numbers in parentheses at the end of the equations refer to the equations in IEC 60865-1:2011.
- c) The system voltages are referred to as nominal voltages.
- d) The results are rounded to three significant digits.
- e) Short-circuit effects appear as exceptional load in addition to the mechanical loads of the normal operation of a switchgear. In the following examples with rigid conductors, a possible static preloading is therefore calculated too. Depending on whether it concerns the load of the normal operation or the load during the short-circuit different safety factors come to use. The height of these factors has been chosen typically and is recommended for the use. However, other safety factors may be necessary depending on the safety concept.

2 Normative references

IEC 60865-1:2011, *Short-Circuit Currents – Calculation of Effects – Part 1: Definitions and calculation methods*

IEC 60909-0:2001, *Short-circuit currents in three-phase AC systems – Part 0: Calculation of currents*