

TECHNICAL REPORT



**High-voltage switchgear and controlgear –
Part 307: Guidance for the extension of validity of type tests of AC metal and
solid-insulation enclosed switchgear and controlgear for rated voltages above
1 kV and up to and including 52 kV**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-8327-0060-0

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	9
4 Use of extension criteria	10
4.1 General.....	10
4.2 Parameters for extension criteria	11
4.3 Use of calculations.....	12
4.3.1 General	12
4.3.2 Temperature rise calculations	12
4.3.3 Electric field calculations	12
4.3.4 Mechanical stress calculations.....	13
4.3.5 Short-circuit current calculations.....	13
4.3.6 Internal arc pressure rise calculations.....	13
4.4 Information needed for extension of type test validity	13
4.5 Extension of validity when using different insulating gas or gas mixture	14
5 Application of extension criteria	15
5.1 General.....	15
5.2 Dielectric tests	15
5.3 Continuous current tests	17
5.4 Mechanical tests	20
5.5 Short-time withstand current and peak withstand current tests	21
5.6 Making and breaking tests	22
5.7 Internal arc fault tests	23
5.7.1 General	23
5.7.2 Extension criteria with respect to the switchgear and controlgear design	23
5.7.3 Extension criteria with respect to ratings and installation conditions	25
6 Typical processes for the application of the extension of the validity of type tests.....	26
6.1 General.....	26
6.2 Extension of validity of a test report to other functional units (situation a)	26
6.3 Validation of a family by selection of test objects (situation b).....	27
6.3.1 General	27
6.3.2 Mapping of the family	28
6.3.3 Specification of test objects	29
6.4 Validation of an assembly by existing test reports (situation c).....	29
6.5 Validation of a design modification (situation d)	30
Annex A (informative) Rationale for the extension criteria	32
A.1 General.....	32
A.2 Dielectric tests	32
A.2.1 General	32
A.2.2 Clearances (items 1 and 2).....	32
A.2.3 Insulating supports and material (items 3 and 4).....	32
A.2.4 Live parts (items 5 and 6)	33
A.2.5 Open contact gap and isolating distance (items 7 and 8)	33
A.2.6 Minimum functional pressure for insulation (item 9)	33
A.2.7 Minimum ambient temperature in service (item 10).....	33

A.2.8	Minimum dielectric properties of insulation gas or gas mixture (item 11)	34
A.3	Continuous current tests	34
A.3.1	General	34
A.3.2	Centre distance between phase conductors (item 1)	34
A.3.3	Phase to earth distance (item 2)	35
A.3.4	Enclosure and compartment volume (item 3)	35
A.3.5	Pressure (density) of insulating gas (item 4)	35
A.3.6	Conductors (items 5 and 6).....	35
A.3.7	Conductor joints and connections (items 7, 8 and 9).....	36
A.3.8	Ventilation area of partitions and enclosure (item 10)	36
A.3.9	Power dissipation of components (item 11).....	36
A.3.10	Insulating barriers (Item 12).....	37
A.3.11	Insulating coating of conductors and enclosures (items 13 and 14).....	37
A.3.12	Insulating material in contact with conductors (item 15)	37
A.3.13	Minimum thermal performance of gas or gas mixture (item 16)	37
A.4	Mechanical tests	38
A.4.1	General	38
A.4.2	Shutter systems (item 1).....	38
A.4.3	Contacts of removable parts (item 2)	39
A.4.4	Interlocking systems (items 3 and 4).....	39
A.5	Short-time withstand current and peak withstand current tests	40
A.5.1	General	40
A.5.2	Centre distance between phase conductors (item 1).....	40
A.5.3	Conductors (items 2, 5 and 6).....	40
A.5.4	Insulating conductor supports (items 3 and 4).....	41
A.5.5	Insulating material in contact with conductors (item 7)	41
A.5.6	Enclosure, partitions or bushings (item 8)	41
A.5.7	Contacts of removable part (item 9).....	41
A.6	Making and breaking tests	41
A.6.1	General	41
A.6.2	Clearance between phases and to earth (items 1 and 2).....	42
A.6.3	Enclosure and compartment volume (item 3)	42
A.6.4	Insulating gas (item 4)	42
A.6.5	Conductors (items 5 and 6).....	42
A.6.6	Insulating supports (items 7, 8 and 9)	43
A.6.7	Dielectric withstand capability (item 10).....	43
A.7	Internal arc fault tests	43
A.7.1	General	43
A.7.2	Clearance between phases and to earth (items 1 and 2).....	43
A.7.3	Compartment volume (item 3).....	44
A.7.4	Pressure of insulating gas (item 4)	44
A.7.5	Material in the region of arc initiation (items 5, 6, 7 and 8).....	44
A.7.6	Pressure relief opening devices (items 9, 10 and 11).....	45
A.7.7	Enclosure and compartments (items 12, 13, 14 and 15).....	45
A.8	Rationale for extension criteria with respect to arc fault ratings and installation conditions	45
A.8.1	General	45
A.8.2	Rated arc fault current and duration (items 1 and 2)	46
A.8.3	Rated voltage (item 3)	46

A.8.4	Rated frequency (item 4)	46
A.8.5	Arrangement of assembly (items 5, 6 and 7)	46
A.8.6	Indoor or outdoor installation (item 8)	46
A.8.7	Type of accessibility (item 9)	46
A.8.8	Accessible sides (item 10)	47
Annex B (informative)	Examples for the extension of validity of type tests.....	48
B.1	General.....	48
B.2	Design modification of a cable terminal in air insulated switchgear and controlgear (AIS)	48
B.3	Design modification of an AIS bus riser functional unit by adding current transformers	49
B.4	Design modification of a key-lock in the door of a functional unit of AIS	51
B.5	Extension of a ring-main unit (RMU) of gas insulated type to functional units with larger width.....	51
B.6	Extension of a family of gas insulated switchgear and controlgear (GIS) by a functional unit	53
B.7	Extension of a GIS with insulation gas-A to insulation gas-B	55
Bibliography	57

Figure 1	– Example for extension of validity of test report for dielectric testing with regard to different construction design variants and insulation gases of the same family of switchgear and controlgear	14
Figure 2	– Extension of validity of one test report – Situation a).....	27
Figure 3	– Validation of a family by selection of appropriate test objects – Situation b)	28
Figure 4	– Validation of actual assembly with existing test reports – Situation c).....	30
Figure 5	– Validation of a design modification – Situation d)	31
Figure B.1	– Cable terminals in the connection compartment of AIS.....	48
Figure B.2	– Addition of block-type current transformers into the bus riser functional unit of AIS.....	50
Figure B.3	– Special type of key-lock as replacement for a standard key-lock in the door of AIS	51
Figure B.4	– Front view and top cross-sectional view of a combination of functional units making up a RMU	52
Figure B.5	– Cross-section of two different functional units of GIS	54
Table 1	– Examples of design parameters.....	11
Table 2	– Extension criteria for dielectric withstand tests	15
Table 3	– Extension criteria for continuous current performance	18
Table 4	– Extension criteria for mechanical performance	20
Table 5	– Extension criteria for short-time and peak withstand current performance	21
Table 6	– Extension criteria for making and breaking capacity	22
Table 7	– Extension criteria for internal arc fault withstand performance	24
Table 8	– Extension criteria for internal arc fault classification with respect to installation conditions	25
Table B.1	– Affirmation of extension criteria with respect to dielectric withstand performance of a functional unit.....	49
Table B.2	– Affirmation of extension criteria with respect to short-time current withstand performance of a functional unit	50

Table B.3 – Affirmation of extension criteria with respect to continuous current performance of a RMU 53

Table B.4 – Affirmation of extension criteria with respect to internal arc classification of a GIS circuit-breaker compartment..... 54

Table B.5 – Reference test results for lightning impulse voltage tests 55

Table B.6 – Reference test results for power-frequency voltage tests 55

Table B.7 – Extension criteria for dielectric withstand tests 56

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 307: Guidance for the extension of validity of type tests of AC metal and solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 62271-307 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear. It is a Technical Report.

This second edition cancels and replaces the first edition published in 2015. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Structure of document updated.
- b) Updated references to IEC 62271-200:2021 and IEC 62271-1:2017.

- c) Addition of criteria for the extension of validity of type tests from functional unit(s) with a different insulating gas to the functional unit to be validated.
- d) Figure 5 for the validation of a design modification was added.
- e) Clause B.7 for the extension of validity of type test for a GIS with insulation gas A to insulation gas B was added.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
17C/939/DTR	17C/957/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62271 series, published under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

This Technical Report is to be used in conjunction with IEC 62271-1:2017, IEC 62271-200:2021, and IEC 62271-201:2014 to which it refers and which are applicable unless otherwise specified.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 307: Guidance for the extension of validity of type tests of AC metal and solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV

1 Scope

This part of IEC 62271, which is a Technical Report, refers to prefabricated metal-enclosed and solid-insulation enclosed (both hereinafter called enclosed) switchgear and controlgear assemblies for alternating current of rated voltages above 1 kV and up to and including 52 kV as specified in IEC 62271-200 and IEC 62271-201, and to other equipment included in the same enclosure with any possible mutual influence.

This document can be used for the extension of the validity of type tests performed on one test object with a defined set of ratings to another switchgear and controlgear assembly of the same family with a different set of ratings or different arrangements of components or insulating fluids. It supports the selection of representative test objects composed of functional units of a family of switchgear and controlgear aimed at the optimization of type tests in order to perform a consistent conformity assessment.

The extension of validity, as this is the case for type tests, does not cover ageing, material compatibility, human health toxicity or impact on the environment, among others. It is the task of the manufacturer and the user to check those aspects are covered for the technical validation of an assembly design.

The extension of validity of type tests according to a component standard is outside the scope of this document.

This document utilises a combination of sound technical and physical principles, manufacturer and user experience, and calculations to establish guidance for the extension of validity of type tests, covering various design and rating aspects.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-151:2001, *International Electrotechnical Vocabulary (IEV) – Part 151: Electrical and magnetic devices*

IEC 60050-441:1984, *International Electrotechnical Vocabulary (IEV) – Part 441: Switchgear, controlgear and fuses*
IEC 60050-441:1984/AMD1:2000

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*
IEC 62271-1:2017/AMD1:2021

IEC 62271-200:2021, *High-voltage switchgear and controlgear – Part 200: AC metal-enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*

IEC 62271-201:2014, *High-voltage switchgear and controlgear – Part 201: AC solid-insulation enclosed switchgear and controlgear for rated voltages above 1 kV and up to and including 52 kV*