

# TECHNICAL REPORT

---

**Fire prevention measures on converters for high-voltage direct current (HVDC) systems, static var compensators (SVC) and flexible ac transmission systems (FACTS) and their valve halls**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

---

ICS 13.220.20

ISBN 978-2-8322-2788-6

**Warning! Make sure that you obtained this publication from an authorized distributor.**

## CONTENTS

FOREWORD.....	5
1 Scope.....	7
2 Normative references .....	7
3 Terms and definitions .....	7
4 Fire hazards in valves and valve halls .....	13
4.1 General.....	13
4.2 Possible causes.....	13
4.2.1 Valve insulation failure .....	13
4.2.2 Loose connections or high resistance joints in the power circuit.....	13
4.2.3 Valve component failures.....	14
4.2.4 Semiconductor device level connections.....	15
4.2.5 Coolant system problems.....	16
4.2.6 Failure of valve hall bushings .....	17
4.2.7 Failure of surge arresters .....	17
4.2.8 False operation of deluge system .....	17
4.2.9 Other valve hall equipment .....	17
4.2.10 Work in and around valve hall.....	17
4.3 Assessment of possible consequences .....	18
5 Valve hall layout and access.....	18
5.1 Physical arrangements.....	18
5.1.1 General .....	18
5.1.2 Present practices.....	19
5.1.3 Specific provisions.....	19
5.2 HVDC valve hall construction.....	19
5.2.1 General .....	19
5.2.2 Valve hall construction.....	20
5.3 Means of egress .....	20
6 Supervision of valve components and other valve hall equipment.....	20
6.1 General.....	20
6.2 Supervision of valve components.....	21
6.2.1 General .....	21
6.2.2 On-line monitoring .....	21
6.2.3 Off-line checks and inspection .....	22
6.3 Supervision of other valve hall equipment.....	22
7 Fire detection systems.....	23
7.1 General.....	23
7.2 Detection and operating principles .....	23
7.2.1 General .....	23
7.2.2 Air sampling systems.....	23
7.2.3 Infra-red beam smoke detectors .....	23
7.2.4 Arc detector systems .....	24
7.2.5 Infra-red flame detectors.....	24
7.2.6 Ultraviolet (UV) flame detectors .....	24
7.2.7 Imaging video camera systems.....	24
7.3 Guidelines for valve hall fire detection.....	24
8 Fire suppression systems .....	24

8.1	General.....	24
8.2	Design considerations for an installed fire suppression system .....	25
8.3	Types of fire extinguishing agents.....	26
8.3.1	List of agents.....	26
8.3.2	Carbon dioxide .....	26
8.3.3	Inert gases .....	26
8.3.4	Hydro fluorocarbons .....	26
8.3.5	Other gases.....	27
8.4	Installation requirements.....	27
8.5	Guidelines for fire extinguishing agents.....	27
9	Vent management .....	28
9.1	General.....	28
9.2	Design considerations.....	29
9.2.1	General .....	29
9.2.2	Natural ventilation.....	29
9.2.3	Forced ventilation .....	30
9.2.4	Design.....	30
10	Control and integration of fire detection, fire protection and converter control systems.....	30
10.1	General.....	30
10.2	Fire alarm classification .....	31
10.2.1	General .....	31
10.2.2	Classification by detection principle .....	32
10.2.3	Classification by detection objective .....	32
10.2.4	Detection system reliability .....	33
10.3	Fire control system .....	33
10.3.1	General .....	33
10.3.2	Basic system functions .....	33
10.3.3	Other system components .....	34
10.3.4	Outline of system design .....	34
10.4	Guidelines for integrated fire control systems.....	35
11	Fire fighting and maintenance.....	35
11.1	General.....	35
11.2	Role of station and fire fighting personnel .....	35
11.2.1	General .....	35
11.2.2	Actions in case of a fire .....	35
11.2.3	Fire fighting .....	36
12	Guidance for purchaser specifications .....	36
12.1	General.....	36
12.2	Purchaser specification .....	36
12.2.1	General .....	36
12.2.2	Semiconductor valves.....	37
12.2.3	Other valve hall equipment .....	38
12.2.4	Valve hall construction.....	38
12.2.5	Fire detection systems.....	38
12.2.6	Fire suppression systems .....	39
12.2.7	Vent management system.....	39
12.2.8	Fire alarm and control systems .....	39
Annexe A (informative)	Valve hall fire hazards and survey of fire incidents .....	40

A.1	General.....	40
A.2	Hazard categories.....	40
A.3	Reports from HVDC users.....	41
A.4	Reported incidents.....	42
A.4.1	Overheating of valve components due to reduced cooling.....	42
A.4.2	Valve component failures.....	44
A.4.3	Loose or high resistance connections in the load current carrying circuit .....	57
A.4.4	Failure of auxiliary circuit electrical connections .....	58
A.4.5	Insulation failures .....	58
A.4.6	Failures of equipment associated with the valve hall.....	61
A.4.7	False alarms.....	62
A.4.8	Unknown causes .....	63
A.5	Conclusion and recommendations.....	63
	Bibliography.....	65
	Figure 1 – Types of ventilation .....	29
	Figure 2 – Possible arrangements and interconnections of an integrated fire detection and control system.....	32
	Table 1 – Fire extinguishing agents .....	26
	Table A.1 – HVDC converters owners/suppliers reference list (May 2012) .....	41

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

---

**FIRE PREVENTION MEASURES ON CONVERTERS FOR  
HIGH-VOLTAGE DIRECT CURRENT (HVDC) SYSTEMS, STATIC  
VAR COMPENSATORS (SVC) AND FLEXIBLE AC TRANSMISSION  
SYSTEMS (FACTS) AND THEIR VALVE HALLS**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC/TR 62757, which is a technical report, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

The text of this technical report is based on the following documents:

Enquiry draft	Report on voting
22F/347/DTR	22F/353A/RVC

Full information on the voting for the approval of this technical report can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

# **FIRE PREVENTION MEASURES ON CONVERTERS FOR HIGH-VOLTAGE DIRECT CURRENT (HVDC) SYSTEMS, STATIC VAR COMPENSATORS (SVC) AND FLEXIBLE AC TRANSMISSION SYSTEMS (FACTS) AND THEIR VALVE HALLS**

## **1 Scope**

IEC TR 62757, which is a technical report, deals with fire prevention measures on converters and their valve halls for high voltage direct current (HVDC) systems, static VAR compensators (SVC) and flexible AC transmission systems (FACTS). It is intended to be primarily for the use of the utilities and consultants who are responsible for issuing technical specifications for new converter valves and valve halls. It concerns fire incidents in HVDC projects using line commutated converters (LCC) or voltage sourced converter (VSC) technology and it is from these projects that most examples of fires and fire incidents are taken. This technical report also addresses converter valves and valve halls for SVC and FACTS.

This technical report provides general recommendations to be considered while preparing specifications for these systems. Specific requirements for a particular project need to be clearly specified and mutually agreed upon between the supplier and the purchaser.

## **2 Normative references**

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

Void.