

TECHNICAL REPORT



Assessment of contact current related to human exposure to electric, magnetic and electromagnetic fields

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 17.220.20

ISBN 978-2-8322-9431-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms and definitions	7
4 Abbreviated terms	8
5 Contact current in EMF guidelines	8
6 Consideration in evaluating contact currents.....	9
6.1 General.....	9
6.2 Assumed situations of human exposure to contact current.....	9
6.2.1 General	9
6.2.2 Capacitive coupling (power line)	9
6.2.3 Inductive coupling (power line)	9
6.2.4 Induction heating equipment.....	9
6.2.5 Wireless power transfer (WPT)	10
6.2.6 Broadcasting	10
6.3 Methods of measurement of touch current used in electrical safety standards.....	10
6.3.1 General	10
6.3.2 IEC standards related to electrical safety.....	10
6.3.3 Modelling human body impedance	13
6.4 Proposed methods of measuring contact current.....	15
6.4.1 General	15
6.4.2 Contact current measurement using a human subject.....	16
6.4.3 Contact current measurement using a human equivalent impedance/circuit.....	16
6.4.4 Contact current calculated from measurement of open-circuit voltage.....	16
7 Consideration in standardization of evaluation method for contact current	17
Annex A (informative) Contact current limits in international EMF guidelines.....	18
A.1 General.....	18
A.2 Reference levels based on electro-stimulation effects	18
A.3 Reference levels and a guidance based on thermal effects	19
Bibliography.....	21
Figure 1 – Time versus current zones of effects of AC currents (15 Hz to 100 Hz) on persons for a current path corresponding to left hand to feet (for explanation see Table 2)	12
Figure 2 – Measuring network for unweighted touch current.....	13
Figure 3 – Measuring network for touch current weighted for perception or startle-reaction [18].....	14
Figure 4 – Impedances of various parts of the body proposed in IEC TS 62996 [10] for 1 kHz to 6 MHz	15
Figure 5 – Realistic computational 3D human body model and results of calculation of current density and pathway	17
Table 1 – Selected IEC technical committees and standards related to electrical safety.....	11

Table 2 – Time versus current zones for AC 15 Hz to 100 Hz for hand to feet pathway
– Summary of zones in Figure 1..... 12

Table A.1 – Reference levels in ICNIRP 2010 guidelines for time varying contact
current from conductive object [1] 18

Table A.2 – Exposure reference levels (ERLs) of contact current based on electro-
stimulation effects in IEEE Std C95.1-2019 [3]..... 18

Table A.3 – Exposure reference levels (ERLs) of contact current based on thermal
effects in IEEE Std C95.1-2019 [3]..... 19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ASSESSMENT OF CONTACT CURRENT RELATED TO HUMAN EXPOSURE TO ELECTRIC, MAGNETIC AND ELECTROMAGNETIC FIELDS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TR 63167 has been prepared by IEC technical committee 106: Methods for the assessment of electric, magnetic and electromagnetic fields associated with human exposure. It is a Technical Report.

This second edition cancels and replaces the first edition published in 2018. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) revised in accordance with the latest revision of international EMF guidelines;
- b) revised in accordance with updates of relevant IEC standards on electrical safety.

The text of this Technical Report is based on the following documents:

Draft	Report on voting
106/641/DTR	106/656/RVDTR

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Report is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

In the guidelines limiting human exposure to electric, magnetic and electromagnetic fields (EMF guidelines), limits or a guidance for the contact current are given to avoid adverse indirect effects, i.e. electric shocks and burn hazards caused by contact with a conductive object located in an electric field or magnetic field or both, when the object has an electric potential owing to electric or magnetic induction to the object.

At the moment, no standardized method for evaluating the contact current, in the context of human exposures to the above fields has been well established. On the other hand, there is a vast amount of knowledge, as well as many standards and regulations on the issue of electrical safety (i.e. direct contact with live part of conductive object) to avoid severe electric shock hazards. Therefore, the evaluation methods used in the field of electrical safety can be useful references. This document summarizes general information on the assessment of contact current related to human exposure to electric, magnetic and electromagnetic fields.

ASSESSMENT OF CONTACT CURRENT RELATED TO HUMAN EXPOSURE TO ELECTRIC, MAGNETIC AND ELECTROMAGNETIC FIELDS

1 Scope

This document, which is a Technical Report, provides general information on the assessment of contact current related to human exposure to electric, magnetic and electromagnetic fields. The contact currents in this context occur when a human body comes into contact with a conductive object that is non-electrified but exposed to an electric field or magnetic field or both at a different electric potential owing to electric or magnetic induction to the object. This is distinguished from the issue of electrical safety where contact with live parts of a conductive object is dealt with.

In reference to the international EMF guidelines [1], [2], and [3]¹, the frequency range of contact current covered in this document is DC to 110 MHz, and only steady-state (continuous) contact currents are covered. Transient contact currents (spark discharges) which can occur immediately before the contact with the object are not covered.

2 Normative references

There are no normative references in this document.

¹ Numbers in square brackets refer to the Bibliography.