

IEC TS 62257-9-8

Edition 2.0 2025-01 REDLINE VERSION

TECHNICAL SPECIFICATION



Renewable energy and hybrid systems for rural electrification off-grid systems Part 9-8: Integrated systems – Requirements for stand-alone renewable energy products with power ratings less than or equal to 350 W

INTERNATIONAL ELECTROTECHNICAL COMMISSION

ISBN 978-2-8327-0145-4

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

F	OREWO	RD	5
IN	TRODU	CTION	8
1	Scop	e	9
2	Norm	ative references	10
3	Term	s and definitions	12
	3.1	Terms related to photometric tests	
	3.7	Component categories	
	3.8	Electrical quantities	
	3.9	Component categories and types, and related terms	
	3.10	Types of connections and connecting devices	
4	Test	requirements	19
	4.1	General	19
	4.1.1	Overview	19
	4.1.2	Product sizes	20
	4.2	Initial testing requirements	22
	4.2.1	General	22
	4.2.2	Quality test method	22
	4.2.3	Accelerated verification method	22
	4.2.4	Pay-as-you-go targeted testing	23
	4.2.5	Product families	24
	4.2.6	'	
	4.2.7	Verification of product identicality	25
	4.2.8		
	4.3	Recurring testing requirements	
	4.4	Retesting of non-conforming products	
	4.5	General testing requirements applicable to all testing pathways	
	4.5.1	General	
	4.5.2	, ,	
_	4.5.3		
5		ty requirements	
	5.1	General	
	5.2	Truth in advertising	
	5.2.1	General	
	5.2.2		
	5.2.3 5.2.4	1 0 1	
	5.2.4 5.2.5	1 7 7 3 1	
	5.2.6	··	
	5.2.7	·	
	5.3	Ports requirements	
	5.3.1	General	
	5.3.2		
	5.3.3	3	
	5.3.4		
	5.3.5		
	5.3.6		

Annex B (normative) Partial shading test for photovoltaic modules	
B.1 General	
B.2 Equipment requirements	
B.3 Test prerequisites	
B.4 Procedure	
B.5 Calculations	
B.6 Pass criteria	
B.7 Reporting	
Annex C (normative) Visual screening and durability tests for photovoltaic modules	
C.1 General	
C.2 Durability of markings test	
C.3 Sharp edge test	
C.4—Screw connections test	
C.5 Impact test	
C.6 Bending or folding test	
C.7 Reporting	
Annex B (informative) List of documentation to solicit	
B.1 General	
B.2 Documentation to request	
Bibliography	95
Figure 1 – Example water protection warning label or instruction	
Figure 3 – Example labelling for a product with four ports having a combined current limit of 3,5 A and a separate port having a current limit of 8 A. The five ports together can supply a total of 11,5 A	75
Figure 4 – Example labelling for a product with five ports having a combined current limit of 8 A and a subset of four ports having a combined current limit of 3,5 A	76
Table 1 – Summary of test requirements and alternatives – Initial testing requirements to determine compliance with Clause 5	20
Table 2 – Summary of test requirements – recurring testing requirements to ensure continued compliance with Clause 5	20
Table 3 – Summary of quality requirements	30
Table 4 – Sample size and renewal requirements for PV tests	
Table 4 – Renewal requirements and acceptable alternative test procedures for PV tests	52
Table 5 – Examples of maximum current ratings	
Table 5 – Default battery deep discharge protection voltage specifications	
Table 6 – Default battery overcharge protection voltage specifications	
Table 7 – Summary of battery safety testing requirements of 5.6.3.1 through 5.6.3.2	
Table 8 – Physical ingress protection requirements	
Table 9 – Water protection requirements	62

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RENEWABLE ENERGY AND HYBRID SYSTEMS FOR RURAL ELECTRIFICATION OFF-GRID SYSTEMS -

Part 9-8: Integrated systems – Requirements for stand-alone renewable energy products with power ratings less than or equal to 350 W

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC TS 62257-9-8:2020. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC TS 62257-9-8 has been prepared by IEC technical committee 82: Solar photovoltaic energy systems. It is a Technical Specification.

This second edition cancels and replaces the first edition issued in 2020. It constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Removed the PV module wiring inspection, partial shading test, and visual screening and durability tests for photovoltaic modules. Applicable tests are now referenced from IEC TS 62257-9-5.
- b) Increased the interval for recurring testing from two years to three years.
- c) Tightened the truth-in-advertising tolerance for numerical aspects other than luminous flux from 15 % to 10 %.
- d) Revised consumer information requirements to allow more flexibility and remove requirements for information that is not known to be valuable to consumers.
- e) Simplified and reorganized the requirements for 12 V and 5 V ports, and allow non-standard output voltages if clearly marked.
- f) Added requirements for ports with USB fast charging support.
- g) Revised the requirements for non-plug-and-play products to allow connectors that require special tools or training in products installed by trained technicians.
- h) Clarified cell- and pack-level safety requirements for single-cell lithium batteries.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
82/2292/DTS	82/2321/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62257 series, published under the general title *Renewable energy* off-grid systems, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- · reconfirmed,
- · withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

The IEC 62257 series provides support and strategies for institutions involved in rural electrification projects. It documents technical approaches for designing, building, testing, and maintaining off-grid renewable energy and hybrid systems with AC nominal voltage below 500 V, DC nominal voltage below 750 V and nominal power below 100 kVA.

This series provides recommendations to support buyers who want to connect with good quality options in the market:

- to choose the right system for the right place,
- to design the system, and
- to operate and maintain the system.

This series is focused only on technical aspects of rural off-grid electrification concentrating on, but not specific to, developing countries. They are not considered as all inclusive to rural electrification. The documents do not describe a range of factors that can determine project or product success: environmental, social, economic, service capabilities, and others. Further developments in this field could be introduced in future steps.

This series is best considered as a whole with different parts corresponding to items for safety, sustainability of systems, and costs. The main objectives are to support the capabilities of households and communities that use small renewable energy and hybrid off-grid systems and inform organizations and institutions in the off-grid power market.

The purpose of this document is to provide baseline standards for quality, durability and truth-in-advertising to protect consumers of stand-alone renewable energy products. This document is specifically related to renewable energy products that are packaged and made available to end-use consumers at the point of purchase as single, stand-alone products that do not require additional system components to function. This document applies to products with peak power ratings of 350 W or less. While most provisions apply to all products in this range, a few are applicable only to products with peak power ratings greater than 10,5 W and less than or equal to 350 W.

The term "stand-alone renewable energy product" is used in this document to describe this class of products. Other equivalent terms, including "off-grid solar" or "rechargeable," are often used by manufacturers companies, distributors, and other stakeholders to describe these products. Many of these systems meet the definition of type T_2I (individual electrification systems with energy storage) in IEC TS 62257-2.

The intended users of this document are:

- Market support programmes that support the off-grid lighting market with financing, consumer education, awareness, and other services;
- manufacturers Companies and distributors that need to verify the quality and performance of products;
- Bulk procurement programmes that facilitate or place large orders of products; and,
- trade regulators such as government policymakers and officials who craft and implement trade and tax policy.

This document establishes minimum requirements for quality standards and warranty requirements. Products are compared to specifications based on test results from IEC TS 62257-9-5 and other information about the product. The requirements are designed to be widely applicable across different markets, countries, and regions.

RENEWABLE ENERGY AND HYBRID SYSTEMS FOR RURAL ELECTRIFICATION OFF-GRID SYSTEMS -

Part 9-8: Integrated systems – Requirements for stand-alone renewable energy products with power ratings less than or equal to 350 W

1 Scope

This part of the IEC 62257 series provides baseline requirements for quality, durability and truth in advertising to protect consumers of off-grid renewable energy products. Evaluation of these requirements is based on tests described in IEC TS 62257-9-5. This document can be used alone or in conjunction with other international standards that address the safety and durability of components of off-grid renewable energy products.

This document applies to stand-alone renewable energy products having the following characteristics:

- The products are powered by photovoltaic (PV) modules or electromechanical power generating devices (such as dynamos), or are designed to use grid electricity to charge a battery or other energy-storage device for off-grid use. The requirements may also be appropriate as guidance for evaluating the quality of-devices products with other power sources, such as thermoelectric generators.
- The peak power rating of the PV module or other power generating device is less than or equal to 350 W.
- All components required to provide basic energy services are sold and installed as a kit, included as a part of a family of products as defined in 4.2.5, or integrated into a single component, including at a minimum:
 - a battery, batteries or other energy storage device(s);
 - power generating device, such as a solar panel, capable of charging the battery, batteries or other energy storage device(s);
 - cables, switches, wiring, connectors and protective devices sufficient to connect the power generating device, power control unit(s) and energy storage device(s).
- The system evaluated includes all the loads (lighting, television, radio, fan, etc.) and load adapter cables that are sold or included as part of the kit or integrated into kit components.
- The PV module maximum power point voltage and the working voltage of any other components in the kit do not exceed 35 V. Exceptions are made for AC-to-DC converters that meet appropriate safety standards, and systems that include PV modules (or combinations of PV modules) with ratings that exceed 240 W at peak power, 35 V at open circuit or 8 A at short circuit are subject to open-circuit voltage greater than 35 V that meet additional safety requirements beyond those assessed in IEC TS 62257-9-5.

NOTE This voltage limit corresponds to the definition of decisive voltage classification A (DVC-A) for wet locations in IEC 62109-1:2010. The limits of 240 W, 35 V and 8 A are consistent with the definition of Class III in IEC 61730-1.

- These requirements cover only DC outputs and loads. Products that include inverters, AC outputs or outlets, or AC appliances are not within the scope of this document. Products can have AC inputs.
- No design expertise is required to choose appropriate system components.
- All electrical connections, except for permanent connections made at the time of installation, can be made using plug-and-socket connectors without the use of any tools. All connections made in the field are straightforward to make and do not require technical expertise, such as wrapping wire in a specific direction, soldering, or crimping.

This document includes provisions related to safety; however, it is not intended to be a comprehensive safety standard. In particular, this document is not intended to be used as an alternative to safety standards such as IEC 62368-1 or the IEC 60335 series for appliances such as radios and televisions that are included with stand-alone renewable energy products. Nor is it intended to replace the safety requirements of IEC 62281 or UN 38.3 for battery safety during transport, or safety requirements of IEC 61730-1 and IEC 61730-2 for PV modules intended for use outside the context of stand-alone renewable energy products.

This document does not address electromagnetic compatibility (EMC). Field experience has not shown EMC to be a major concern in typical applications of stand-alone renewable energy products within the scope of this document. In applications where EMC is a concern (e.g. systems that include medical devices), the standards relevant to the specific application should be referenced.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60335-1, Household and similar electrical appliances – Safety – Part 1: General requirements

IEC 60335-2-29, Household and similar electrical appliances – Safety – Part 2-29: Particular requirements for battery chargers

IEC 60364-7-712:2017, Low voltage electrical installations – Part 7-712: Requirements for special installations or locations – Solar photovoltaic (PV) power supply systems

IEC 60529, Degrees of protection provided by enclosures (IP Code)

IEC 60598-1, Luminaires – Part 1: General requirements and tests

IEC 60904-9, Photovoltaic devices - Part 9: Solar simulator performance requirements

IEC 61215 (all parts), Terrestrial photovoltaic (PV) modules - Design qualification and type approval

IEC 61215-1, Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 1: Test requirements

IEC 61215-2, Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 2: Test procedures

IEC 61730 (all parts). Photovoltaic (PV) module safety qualification

IEC 61730-1, Photovoltaic (PV) module safety qualification – Part 1: Requirements for construction

IEC 61730-2, Photovoltaic (PV) module safety qualification - Part 2: Requirements for testing

IEC TS 61836, Solar photovoltaic energy systems – Terms, definitions and symbols

IEC 62109-1:2010, Safety of power converters for use in photovoltaic power systems – Part 1: General requirements

IEC 62133-2, Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for portable sealed secondary—lithium cells, and for batteries made from them, for use in portable applications – Part 2: Lithium systems

IEC TS 62257-9-5:2024, Recommendations for renewable energy and hybrid systems for rural electrification: Integrated systems – Laboratory evaluation of stand-alone renewable energy products for rural electrification

IEC TS 62257-12-1, Recommendations for renewable energy and hybrid systems for rural electrification – Part 12-1:—Selection Laboratory evaluation of lamps and lighting appliances for off-grid electricity systems

IEC 62281, Safety of primary and secondary lithium cells and batteries during transport

IEC 62368-1, Audio/video, information and communication technology equipment – Part 1: Safety requirements

IEC 62619, Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for secondary lithium cells and batteries, for use in industrial applications

IEC 62790, Junction boxes for photovoltaic modules – Safety requirements and tests

IEC 62930, Electric cables for photovoltaic systems with a voltage rating of 1,5 kV DC

IEC TS 63163, Terrestrial photovoltaic (PV) modules for consumer products – Design qualification and type approval

ISO 4892 (all parts), Plastics – Methods of exposure to laboratory light sources

EN 50618, Electric cables for photovoltaic systems

HD 605, Electric cables - Additional test methods

ANSI/CAN/UL 9540, Energy Storage Systems and Equipment

UL 1741, Standard for inverters, converters, controllers and interconnection system equipment for use with distributed energy resources

UL 1973, Standard for batteries for use in stationary, vehicle auxiliary power and light electric rail (LER) applications

UL 2054, Standard for Household and Commercial Batteries

UL 61730-1, Photovoltaic (PV) module safety qualification – Part 1: Requirements for construction

UL 61730-2, Photovoltaic (PV) module safety qualification – Part 2: Requirements for testing

UL 62133-2, Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for portable sealed secondary cells, and for batteries made from them, for use in portable applications

United Nations. Recommendations on the transport of dangerous goods: manual of tests and criteria, Section 38.3: Lithium batteries (UN 38.3)





Edition 2.0 2025-01

TECHNICAL SPECIFICATION



Renewable energy off-grid systems –
Part 9-8: Integrated systems – Requirements for stand-alone renewable energy products with power ratings less than or equal to 350 W



CONTENTS

F	DREWO	RD	5
IN	TRODU	CTION	7
1	Scop	e	8
2	Norm	ative references	9
3	Term	s and definitions	10
	3.1	Terms related to photometric tests	
	3.7	Component categories	
	3.8	Electrical quantities	
	3.9	Component categories and types, and related terms	
	3.10	Types of connections and connecting devices	
4	Test	requirements	
	4.1	General	17
	4.1.1	Overview	
	4.1.2	Product sizes	18
	4.2	Initial testing requirements	20
	4.2.1	General	20
	4.2.2	Quality test method	20
	4.2.3	Accelerated verification method	20
	4.2.4	Pay-as-you-go targeted testing	21
	4.2.5	Product families	22
	4.2.6	Similar products	22
	4.2.7	Verification of product identicality	23
	4.2.8	Reference to other standards	24
	4.3	Recurring testing requirements	25
	4.4	Retesting of non-conforming products	26
	4.5	General testing requirements applicable to all testing pathways	26
	4.5.1	General	
	4.5.2	, ,	
	4.5.3		
5	Quali	ty requirements	27
	5.1	General	27
	5.2	Truth in advertising	29
	5.2.1	General	
	5.2.2		
	5.2.3		
	5.2.4		
	5.2.5		
	5.2.6	ů i	
	5.2.7	5 5	
	5.3	Ports requirements	
	5.3.1	General	
	5.3.2	3	
	5.3.3		
	5.3.4		
	5.3.5	• 1	
	5.3.6	Functionality requirements	41

5.4	Lumen maintenance	45
5.5	Health and safety	45
5.5.1	AC-DC power supply safety	45
5.5.2	Hazardous substances	46
5.5.3	Overload protection	46
5.5.4	Wiring and connector safety	46
5.5.5	Additional tests for PV modules	47
5.5.6	Requirements for systems with large PV modules or arrays	48
5.6	Battery requirements	
5.6.1	Provision of battery specification sheets	
5.6.2	• •	
5.6.3		
5.6.4	Battery durability	
5.6.5	Authentication of battery documents	
5.7	Quality and durability	
5.7.1	General	
5.7.2	Physical and water ingress protection	
5.7.3	•	
5.7.4	Soldering and electronics quality	
5.7.5		
5.7.6	Strain relief durability	
5.7.7	Outdoor cable durability (size B products only)	
	• , • • • • • • • • • • • • • • • • • •	
5.7.8	5 1	
5.7.9		
5.7.1		
5.8	Consumer information	
5.8.1	Warranty requirements	
5.8.2		
5.8.3	User manual requirements (size B products only)	
5.8.4	Component replacement methods (size B products only)	
5.8.5	Port information requirements	
Annex A (normative) Testing of similar products	
A.1	General	69
A.2	Guidelines	69
A.2.1	Visual screening	69
A.2.2	Lumen maintenance and light output	69
A.2.3	Charge controller testing	70
A.2.4	PV modules	70
A.2.5	Battery durability testing	70
A.2.6	Connector durability testing	70
A.2.7	Battery testing, full-battery run time, solar run time, and energy service calculations	71
A.2.8		
A.2.9	• .	
A.2.1	•	
A.2.1		
A.2.1	•	
A.2.1		
A.2.1		

Annex B (informative) List of documentation to solicit	73
B.1 General	73
B.2 Documentation to request	73
Bibliography	75
Figure 1 – Example water protection warning label or instruction	56
	50
Figure 2 – Decision process to determine whether or not a component is subject to the drop test	57
Figure 3 – Example labelling for a product with four ports having a combined current limit of 3,5 A and a separate port having a current limit of 8 A. The five ports together can supply a total of 11,5 A	67
Figure 4 – Example labelling for a product with five ports having a combined current limit of 8 A and a subset of four ports having a combined current limit of 3,5 A	67
Table 1 – Summary of test requirements and alternatives – Initial testing requirements to determine compliance with Clause 5	18
Table 2 – Summary of test requirements – recurring testing requirements to ensure continued compliance with Clause 5	18
Table 3 – Summary of quality requirements	28
Table 4 – Renewal requirements and acceptable alternative test procedures for PV tests	47
Table 5 – Default battery deep discharge protection voltage specifications	50
Table 6 – Default battery overcharge protection voltage specifications	50
Table 7 – Summary of battery safety testing requirements of 5.6.3.1 through 5.6.3.2	52
Table 8 – Physical ingress protection requirements	54
Table 9 – Water protection requirements	55

INTERNATIONAL ELECTROTECHNICAL COMMISSION

RENEWABLE ENERGY OFF-GRID SYSTEMS -

Part 9-8: Integrated systems – Requirements for stand-alone renewable energy products with power ratings less than or equal to 350 W

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at https://patents.iec.ch. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62257-9-8 has been prepared by IEC technical committee 82: Solar photovoltaic energy systems. It is a Technical Specification.

This second edition cancels and replaces the first edition issued in 2020. It constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Removed the PV module wiring inspection, partial shading test, and visual screening and durability tests for photovoltaic modules. Applicable tests are now referenced from IEC TS 62257-9-5.
- b) Increased the interval for recurring testing from two years to three years.

- c) Tightened the truth-in-advertising tolerance for numerical aspects other than luminous flux from 15 % to 10 %.
- d) Revised consumer information requirements to allow more flexibility and remove requirements for information that is not known to be valuable to consumers.
- e) Simplified and reorganized the requirements for 12 V and 5 V ports, and allow non-standard output voltages if clearly marked.
- f) Added requirements for ports with USB fast charging support.
- g) Revised the requirements for non-plug-and-play products to allow connectors that require special tools or training in products installed by trained technicians.
- h) Clarified cell- and pack-level safety requirements for single-cell lithium batteries.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
82/2292/DTS	82/2321/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62257 series, published under the general title *Renewable energy off-grid systems*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- · reconfirmed,
- withdrawn, or
- revised.

INTRODUCTION

The IEC 62257 series provides support and strategies for institutions involved in rural electrification projects. It documents technical approaches for designing, building, testing, and maintaining off-grid renewable energy and hybrid systems with AC nominal voltage below 500 V, DC nominal voltage below 750 V and nominal power below 100 kVA.

This series provides recommendations to support buyers who want to connect with good quality options in the market:

- · to choose the right system for the right place,
- to design the system, and
- to operate and maintain the system.

This series is focused only on technical aspects of rural off-grid electrification concentrating on, but not specific to, developing countries. They are not considered as all inclusive to rural electrification. The documents do not describe a range of factors that can determine project or product success: environmental, social, economic, service capabilities, and others. Further developments in this field could be introduced in future steps.

This series is best considered as a whole with different parts corresponding to items for safety, sustainability of systems, and costs. The main objectives are to support the capabilities of households and communities that use small renewable energy and hybrid off-grid systems and inform organizations and institutions in the off-grid power market.

The purpose of this document is to provide baseline standards for quality, durability and truth-in-advertising to protect consumers of stand-alone renewable energy products. This document is specifically related to renewable energy products that are packaged and made available to end-use consumers at the point of purchase as single, stand-alone products that do not require additional system components to function. This document applies to products with peak power ratings of 350 W or less. While most provisions apply to all products in this range, a few are applicable only to products with peak power ratings greater than 10,5 W and less than or equal to 350 W.

The term "stand-alone renewable energy product" is used in this document to describe this class of products. Other equivalent terms, including "off-grid solar" or "rechargeable," are often used by companies, distributors, and other stakeholders to describe these products. Many of these systems meet the definition of type T_2I (individual electrification systems with energy storage) in IEC TS 62257-2.

The intended users of this document are:

- Market support programmes that support the off-grid lighting market with financing, consumer education, awareness, and other services;
- Companies and distributors that need to verify the quality and performance of products;
- Bulk procurement programmes that facilitate or place large orders of products; and,
- trade regulators such as government policymakers and officials who craft and implement trade and tax policy.

This document establishes minimum requirements for quality standards and warranty requirements. Products are compared to specifications based on test results from IEC TS 62257-9-5 and other information about the product. The requirements are designed to be widely applicable across different markets, countries, and regions.

RENEWABLE ENERGY OFF-GRID SYSTEMS -

Part 9-8: Integrated systems – Requirements for stand-alone renewable energy products with power ratings less than or equal to 350 W

1 Scope

This part of the IEC 62257 series provides baseline requirements for quality, durability and truth in advertising to protect consumers of off-grid renewable energy products. Evaluation of these requirements is based on tests described in IEC TS 62257-9-5. This document can be used alone or in conjunction with other international standards that address the safety and durability of components of off-grid renewable energy products.

This document applies to stand-alone renewable energy products having the following characteristics:

- The products are powered by photovoltaic (PV) modules or electromechanical power generating devices (such as dynamos), or are designed to use grid electricity to charge a battery or other energy-storage device for off-grid use. The requirements may also be appropriate as guidance for evaluating the quality of products with other power sources, such as thermoelectric generators.
- The peak power rating of the PV module or other power generating device is less than or equal to 350 W.
- All components required to provide basic energy services are sold and installed as a kit, included as a part of a family of products as defined in 4.2.5, or integrated into a single component, including at a minimum:
 - a battery, batteries or other energy storage device(s);
 - power generating device, such as a solar panel, capable of charging the battery, batteries or other energy storage device(s);
 - cables, switches, wiring, connectors and protective devices sufficient to connect the power generating device, power control unit(s) and energy storage device(s).
- The system evaluated includes all the loads (lighting, television, radio, fan, etc.) and load adapter cables that are sold or included as part of the kit or integrated into kit components.
- The PV module maximum power point voltage and the working voltage of any other components in the kit do not exceed 35 V. Exceptions are made for AC-to-DC converters that meet appropriate safety standards, and systems that include PV modules (or combinations of PV modules) with open-circuit voltage greater than 35 V that meet additional safety requirements beyond those assessed in IEC TS 62257-9-5.

NOTE This voltage limit corresponds to the definition of decisive voltage classification A (DVC-A) for wet locations in IEC 62109-1. The limits of 240 W, 35 V and 8 A are consistent with the definition of Class III in IEC 61730-1.

- These requirements cover only DC outputs and loads. Products that include inverters, AC outputs or outlets, or AC appliances are not within the scope of this document. Products can have AC inputs.
- No design expertise is required to choose appropriate system components.
- All electrical connections, except for permanent connections made at the time of installation, can be made using plug-and-socket connectors without the use of any tools.

This document includes provisions related to safety; however, it is not intended to be a comprehensive safety standard. In particular, this document is not intended to be used as an alternative to safety standards such as IEC 62368-1 or the IEC 60335 series for appliances such as radios and televisions that are included with stand-alone renewable energy products. Nor is it intended to replace the safety requirements of IEC 62281 or UN 38.3 for battery safety during transport, or safety requirements of IEC 61730-1 and IEC 61730-2 for PV modules intended for use outside the context of stand-alone renewable energy products.

This document does not address electromagnetic compatibility (EMC). Field experience has not shown EMC to be a major concern in typical applications of stand-alone renewable energy products within the scope of this document. In applications where EMC is a concern (e.g. systems that include medical devices), the standards relevant to the specific application should be referenced.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60335-1, Household and similar electrical appliances – Safety – Part 1: General requirements

IEC 60335-2-29, Household and similar electrical appliances – Safety – Part 2-29: Particular requirements for battery chargers

IEC 60364-7-712:2017, Low voltage electrical installations – Part 7-712: Requirements for special installations or locations – Solar photovoltaic (PV) power supply systems

IEC 60529, Degrees of protection provided by enclosures (IP Code)

IEC 60598-1, Luminaires – Part 1: General requirements and tests

IEC 61215-1, Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 1: Test requirements

IEC 61215-2, Terrestrial photovoltaic (PV) modules – Design qualification and type approval – Part 2: Test procedures

IEC 61730-1, Photovoltaic (PV) module safety qualification – Part 1: Requirements for construction

IEC 61730-2, Photovoltaic (PV) module safety qualification – Part 2: Requirements for testing

IEC TS 61836, Solar photovoltaic energy systems – Terms, definitions and symbols

IEC 62109-1, Safety of power converters for use in photovoltaic power systems – Part 1: General requirements

IEC 62133-2, Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for portable sealed secondary cells, and for batteries made from them, for use in portable applications – Part 2: Lithium systems

– 10 **–**

IEC TS 62257-9-5:2024, Recommendations for renewable energy and hybrid systems for rural electrification: Integrated systems – Laboratory evaluation of stand-alone renewable energy products for rural electrification

IEC TS 62257-12-1, Recommendations for renewable energy and hybrid systems for rural electrification – Part 12-1: Laboratory evaluation of lamps and lighting appliances for off-grid electricity systems

IEC 62281, Safety of primary and secondary lithium cells and batteries during transport

IEC 62368-1, Audio/video, information and communication technology equipment – Part 1: Safety requirements

IEC 62619, Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for secondary lithium cells and batteries, for use in industrial applications

IEC 62790, Junction boxes for photovoltaic modules - Safety requirements and tests

IEC TS 63163, Terrestrial photovoltaic (PV) modules for consumer products – Design qualification and type approval

ISO 4892 (all parts), Plastics – Methods of exposure to laboratory light sources

ANSI/CAN/UL 9540, Energy Storage Systems and Equipment

UL 1741, Standard for inverters, converters, controllers and interconnection system equipment for use with distributed energy resources

UL 1973, Standard for batteries for use in stationary, vehicle auxiliary power and light electric rail (LER) applications

UL 2054, Standard for Household and Commercial Batteries

UL 61730-1, Photovoltaic (PV) module safety qualification – Part 1: Requirements for construction

UL 61730-2, Photovoltaic (PV) module safety qualification – Part 2: Requirements for testing

UL 62133-2, Secondary cells and batteries containing alkaline or other non-acid electrolytes – Safety requirements for portable sealed secondary cells, and for batteries made from them, for use in portable applications

United Nations. Recommendations on the transport of dangerous goods: manual of tests and criteria, Section 38.3: Lithium batteries (UN 38.3)