

TECHNICAL SPECIFICATION



**High-voltage switchgear and controlgear –
Part 318: DC gas-insulated metal-enclosed switchgear for rated voltages
including and above 100 kV**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.130.10

ISBN 978-2-8322-9674-5

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	8
1 Scope.....	10
2 Normative references	10
3 Terms and definitions	12
4 Normal and special service conditions	16
4.1 Normal service conditions	16
4.2 Special service conditions.....	16
4.101 General.....	17
5 Ratings.....	17
5.1 General.....	17
5.2 Rated direct voltage (U_{rd}).....	17
5.3 Rated insulation level (U_{dd} , U_p , U_s)	18
5.4 Rated continuous current (I_{rd})	18
5.5 Rated values of short-time withstand current.....	18
5.5.1 Typical waveform of short-circuit current.....	18
5.5.2 Rated short-time withstand direct current (I_{kd})	18
5.5.3 Rated peak withstand current (I_{pd}).....	18
5.5.4 Rated duration of short-circuit (t_{kd}).....	18
5.6 Rated supply voltage of auxiliary and control circuits (U_a)	18
5.7 Rated supply frequency of auxiliary and control circuits	18
5.8 Rated pressure of compressed gas supply for controlled pressure systems	18
6 Design and construction	19
6.1 Requirements for liquids in switchgear and controlgear.....	19
6.2 Requirements for gases in switchgear and controlgear	19
6.3 Earthing of switchgear and controlgear	19
6.3.101 Earthing of the main circuit	19
6.3.102 Earthing of the enclosure.....	19
6.4 Auxiliary and control equipment and circuits	19
6.5 Dependent power operation	19
6.6 Stored energy operation.....	19
6.7 Independent unlatched operation (independent manual or power operation)	19
6.8 Manually operated actuators	20
6.9 Operation of releases.....	20
6.10 Pressure/level indication	20
6.11 Nameplates.....	20
6.12 Locking devices	21
6.13 Position indication.....	21
6.14 Degrees of protection provided by enclosures.....	21
6.15 Creepage distances for outdoor insulators	21
6.16 Gas and vacuum tightness.....	21
6.16.1 General	21
6.16.2 Controlled pressure systems for gas.....	21
6.16.3 Closed pressure systems for gas	21
6.16.4 Sealed pressure systems.....	22
6.16.101 Leakage	22

6.16.102	Gas handling	22
6.17	Tightness for liquid systems	22
6.18	Fire hazard (flammability)	22
6.19	Electromagnetic compatibility (EMC)	22
6.20	X-Ray emission	22
6.21	Corrosion	23
6.22	Filling levels for insulation, switching and/or operation	23
6.101	General requirements for DC GIS	23
6.102	Pressure coordination	23
6.103	Internal arc fault	24
6.103.1	General	24
6.103.2	External effects of the arc	25
6.103.3	Internal fault location	26
6.104	Enclosures	26
6.104.1	General	26
6.104.2	Design of enclosures	26
6.105	Partitions	27
6.105.1	Design of partitions	27
6.105.2	Partitioning	27
6.106	Pressure relief	29
6.106.1	General	29
6.106.2	Non-reclosing pressure relief device	29
6.106.3	Pressure relief valve	29
6.106.4	Limitation of pressure rise in the case of an internal fault	30
6.107	Noise	30
6.108	Interfaces	30
6.108.1	General	30
6.108.2	Cable connections	30
6.108.3	Direct transformer connections	31
6.108.4	Bushings	31
6.108.5	Interfaces for future extensions	31
6.109	Interlocking	32
7	Type tests	32
7.1	General	32
7.1.1	General remarks	32
7.1.2	Information for identification of test objects	33
7.1.3	Information to be included in type-test reports	33
7.2	Dielectric tests	33
7.2.1	General	33
7.2.2	Ambient air conditions during tests	34
7.2.3	Wet test procedure	34
7.2.4	Arrangement of the equipment	34
7.2.5	Criteria to pass the test	34
7.2.6	Application of the test voltage and test conditions	34
7.2.7	Tests of switchgear and controlgear	35
7.2.8	Artificial pollution tests for outdoor insulators	36
7.2.9	Partial discharge tests	36
7.2.10	Dielectric tests on auxiliary and control circuits	38
7.2.11	Voltage test as condition check	38

7.2.101	DC insulation system test	38
7.2.102	Long-term energized test	41
7.3	Resistance measurement	41
7.3.1	Measurement of the resistance of auxiliary contacts class 1 and class 2	41
7.3.2	Measurement of the resistance of auxiliary contacts class 3	41
7.3.3	Electrical continuity of earthed metallic parts test	41
7.3.4	Resistance measurement of contacts and connections in the main circuit as a condition check	42
7.4	Continuous current tests	42
7.4.1	Conditions of the test object	42
7.4.2	Arrangement of the equipment	42
7.4.3	Test current and duration	42
7.4.4	Temperature measurement during test	42
7.4.5	Resistance of the main circuit	43
7.4.6	Criteria to pass test	43
7.5	Short-time withstand current and peak withstand current tests	43
7.5.1	General	43
7.5.2	Arrangement of the equipment and of the test circuit	43
7.5.3	Test current and duration	43
7.5.4	Conditions of the test object after test	43
7.5.101	Tests on the main circuits	43
7.5.102	Tests on earthing circuits	44
7.6	Verification of the protection	44
7.6.1	General	44
7.6.2	Verification of the IP coding	44
7.6.3	Verification of the IK coding	44
7.7	Tightness tests	44
7.7.1	General	44
7.7.2	Controlled pressure systems for gas	44
7.7.3	Closed pressure systems for gas	45
7.7.4	Sealed pressure systems	45
7.7.5	Liquid tightness tests	45
7.8	Electromagnetic compatibility tests (EMC)	45
7.9	Additional tests on auxiliary and control circuits	45
7.10	X-radiation test for vacuum interrupters	45
7.101	Verification of making and breaking capacities	45
7.102	Mechanical and environmental tests	45
7.102.1	General	45
7.102.2	Mechanical operation test at ambient temperature	45
7.102.3	Low- and high-temperature test	46
7.103	Proof tests for enclosures	46
7.103.1	General	46
7.103.2	Burst test procedure	46
7.103.3	Strain measurement test	47
7.104	Pressure test on partitions	47
7.105	Test under conditions of arcing due to an internal fault	48
7.106	Insulator tests	48
7.106.1	General	48
7.106.2	Thermal performance	48

7.106.3	Tightness test for partitions	49
7.107	Corrosion test on earthing connections	49
7.107.1	General	49
7.107.2	Test procedure	49
7.107.3	Criteria to pass the test	49
7.108	Corrosion tests on sealing systems of enclosures and auxiliary equipment	50
7.108.1	General	50
7.108.2	Test procedure	50
7.108.3	Criteria to pass the test	50
8	Routine tests	50
8.1	General.....	50
8.2	Dielectric test on the main circuit	51
8.2.101	Alternating or direct voltage tests on the main circuit	51
8.2.102	Partial discharge measurement.....	51
8.3	Tests on auxiliary and control circuits	51
8.4	Measurement of the resistance of the main circuit.....	52
8.5	Tightness test	52
8.6	Design and visual checks	52
8.101	Pressure tests of enclosures	52
8.102	Mechanical operation tests	52
8.103	Tests on auxiliary circuits, equipment and interlocks in the control mechanism	53
8.104	Pressure test on partitions	53
9	Guide to the selection of switchgear and controlgear (informative)	53
9.1	General.....	53
9.2	Selection of rated values.....	53
9.3	Cable-interface considerations.....	53
9.4	Continuous or temporary overload due to changed service conditions.....	53
9.5	Environmental aspects.....	53
10	Information to be given with enquiries, tenders and orders (informative).....	54
10.1	General.....	54
10.2	Information with enquiries and orders	54
10.3	Information with tenders.....	54
11	Transport, storage, installation, operating instructions and maintenance.....	54
11.1	General.....	54
11.2	Conditions during transport, storage and installation	54
11.3	Installation	54
11.4	Operating instructions	54
11.5	Maintenance	54
11.101	Tests after installation on-site	54
11.101.1	General	54
11.101.2	Dielectric tests on the main circuits.....	55
11.101.3	Dielectric tests on auxiliary circuits	59
11.101.4	Measurement of the resistance of the main circuit	59
11.101.5	Gas tightness tests	59
11.101.6	Checks and verifications.....	59
11.101.7	Gas quality verifications.....	59
12	Safety.....	60

13	Influence of the product on the environment	60	
	Annex A (normative) Methods for alternating current testing of DC gas-insulated metal-enclosed switchgear under conditions of arcing due to an internal fault	61	
	A.1	General.....	61
	A.2	Short-circuit current arcing test	61
	A.2.1	Test arrangements.....	61
	A.2.2	Current and voltage applied.....	61
	A.2.3	Test procedure	62
	A.2.4	Criteria to pass the test	62
	A.2.5	Test report.....	63
	A.2.6	Extension of the test results.....	63
	A.3	Composite verification by calculation and separate tests.....	63
	Annex B (informative) Technical and practical considerations of site testing	64	
	B.1	Test voltage generators	64
	B.2	Locating discharges	64
	B.3	Special test procedures	64
	B.3.1	General	64
	B.3.2	Testing at reduced voltage.....	65
	B.3.3	Testing at reduced gas density	65
	B.4	Partial discharge measurements	65
	B.5	Electrical conditioning	65
	B.6	Repetition tests.....	65
	B.6.1	General	65
	B.6.2	Recommended procedure.....	66
	B.7	Partial discharge detection method	66
	B.7.1	General	66
	B.7.2	Conventional method according to IEC 60270.....	66
	B.7.3	VHF/UHF method	66
	B.7.4	Acoustic method.....	67
	B.7.5	Sensitivity verification of acoustic and UHF method.....	68
	Annex C (informative) Calculation of pressure rise due to an internal fault.....	69	
	Annex D (informative) Information to be given with enquiries, tenders and orders	70	
	D.1	General.....	70
	D.2	Normal and special service conditions	70
	D.3	Ratings	71
	D.4	Design and construction.....	72
	D.5	Bus ducts.....	72
	D.6	Disconnecter and earthing switch.....	73
	D.7	Bushing	73
	D.8	Cable connection	73
	D.9	Transformer connection	74
	D.10	Current transducer.....	74
	D.11	Voltage transducer.....	74
	D.12	Metal-oxide surge arrester	74
	D.13	Documentation for enquiries and tenders	75
	Annex E (informative) List of notes concerning certain countries.....	76	
	Annex F (informative) Long-term energized test.....	77	
	F.1	Test objects	77

F.2	Test sequence	77
F.3	Pre-test.....	79
F.4	Condition check	79
F.5	Success criteria, re-testing and interruptions	79
Annex G (informative) Application of DC GIS under composite voltage of alternating and direct voltage components		81
G.1	General.....	81
G.2	Composite voltage consisting of alternating and direct voltage components	81
G.3	Recommendation for application of DC GIS in bipolar DC schemes under composite voltage stress.....	82
Annex H (informative) DC switchgear located on neutral buses.....		83
Bibliography.....		84
Figure 1 – Pressure coordination		24
Figure 2 – Example of arrangement of enclosures and gas compartments		29
Figure G.1 – Composite phase-to-earth voltage at midpoint of converter pole including third harmonic content and simplified voltage curve		81
Table 1 – Reference table of service conditions relevant to DC GIS.....		17
Table 2 – Performance criteria		25
Table 3 – Type tests		33
Table 4 – Test voltage for measuring PD intensity		37
Table 5 – Sequence of DC insulation system test		40
Table 6 – On-site test voltages		57
Table D.1 – Normal and special service conditions		70
Table D.2 – Ratings		71
Table D.3 – Design and construction.....		72
Table D.4 – Bus ducts.....		72
Table D.5 – Bushing		73
Table D.6 – Cable connection		73
Table D.7 – Transformer connection		74
Table D.8 – Current transducer.....		74
Table D.9 – Voltage transducer.....		74
Table D.10 – Documentation for enquiries and tenders		75
Table F.1 – Test sequence for long-term energized test.....		77
Table F.2 – Test sequence for long-term energized test with combined switching and lightning impulse voltage tests and changed sequence		78
Table F.3 – Test procedure for the long-term energized test		79
Table F.4 – Condition check for the long-term energized test.....		79

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 318: DC gas-insulated metal-enclosed switchgear
for rated voltages including and above 100 kV**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62271-318 has been prepared by subcommittee 17C: Assemblies, of IEC technical committee 17: High-voltage switchgear and controlgear. It is a Technical Specification.

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
17C/930/DTS	17C/937/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/standardsdev/publications.

The list of all parts of the IEC 62271 series under the general title, *High-voltage switchgear and controlgear*, may be found on the IEC website.

This document should be read in conjunction with IEC TS 62271-5:2024, to which it refers and which is applicable unless otherwise specified. In order to simplify the indication of corresponding requirements, the same numbering of clauses and subclauses is used as in IEC TS 62271-5:2024. Amendments to these clauses and subclauses are given under the same numbering, whilst additional subclauses, are numbered from 101.

The reader's attention is drawn to the fact that Annex E lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this document.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 318: DC gas-insulated metal-enclosed switchgear for rated voltages including and above 100 kV

1 Scope

This part of IEC 62271 specifies requirements for gas-insulated metal-enclosed switchgear in which the insulation is obtained, at least partly, by an insulating gas or gas mixture other than air at atmospheric pressure, for direct current of rated voltages including and above 100 kV, for indoor and outdoor installation. This document includes rules for service conditions, ratings, design, and construction requirements. Test requirements and criteria for proof for passing type and routine tests are defined in this document for development and manufacturing of DC switchgear.

For the purpose of this document, the terms "DC GIS" and "DC switchgear" are used for "DC gas-insulated metal-enclosed switchgear".

This specification is applicable for both Line Commutated Converter (LCC) and Voltage Sourced Converter (VSC) for HVDC systems.

The DC gas-insulated metal-enclosed switchgear covered by this document consists of individual components intended to be directly connected together and able to operate only in this manner.

This document completes and amends, if applicable, the various relevant documents applying to the individual components constituting DC gas-insulated metal-enclosed switchgear.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60060-1:2010, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60085:2007, *Electrical insulation – Thermal evaluation and designation*

IEC 60068-2-11:2021, *Environmental testing – Part 2-11: Tests – Test Ka: Salt mist*

IEC 60068-2-17:2023, *Environmental testing – Part 2-17: Tests – Test Q: Sealing*

IEC/IEEE 60076-57-129:2017, *Power transformers – Part 57-129: Transformers for HVDC applications*

IEC 60099-4:2014, *Surge arresters – Part 4: Metal-oxide surge arresters without gaps for a.c. systems*

IEC 60099-9:2014, *Surge arresters – Part 9: Metal-oxide surge arresters without gaps for HVDC converter stations*

IEC 60137:2017, *Insulated bushings for alternating voltages above 1 000 V*

IEC 60270:2000, *High-voltage test techniques – Partial discharge measurements*
IEC 60270:2000/AMD1:2015

IEC 60376:2018, *Specification of technical grade sulphur hexafluoride (SF₆) and complementary gases to be used in its mixtures for use in electrical equipment*

IEC 60480:2019, *Specifications for the re-use of sulphur hexafluoride (SF₆) and its mixtures in electrical equipment*

IEC TS 60815-1:2008, *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 1: Definitions, information and general principles*

IEC TS 60815-4:2016, *Selection and dimensioning of high-voltage insulators intended for use in polluted conditions – Part 4: Insulators for d.c. systems*

IEC 61869-14:2018, *Instrument transformers – Part 14: Additional requirements for current transformers for DC applications*

IEC 61869-15:2018, *Instrument transformers – Part 15: Additional requirements for voltage transformers for DC applications*

IEC 62271-1:2017, *High-voltage switchgear and controlgear – Part 1: Common specifications for alternating current switchgear and controlgear*

IEC 62271-4, *High-voltage switchgear and controlgear – Part 4: Handling procedures for gases for insulation and/or switching*

IEC TS 62271-5:2024, *High-voltage switchgear and controlgear – Part 5: Common specifications for direct current switchgear*

IEC 62271-209:2019, *High-voltage switchgear and controlgear – Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable terminations*
IEC 62271-209:2019/AMD1:2022

IEC 62271-211:2014, *High-voltage switchgear and controlgear – Part 211: Direct connection between power transformers and gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*

IEC TR 62271-306:2012, *High-voltage switchgear and controlgear – Part 306: Guide to IEC 62271-100, IEC 62271-1 and other IEC standards related to alternating current circuit-breakers*
IEC TR 62271-306:2012/AMD1:2018

IEC TS 62271-313, *High-voltage switchgear and controlgear – Part 313: Direct current disconnectors and earthing switches*

IEC TS 62271-314:2024, *High-voltage switchgear and controlgear – Part 314: Direct current disconnectors and earthing switches*

IEC TS 62271-315:20¹, *High voltage switchgear and controlgear – Part 315: Direct current (DC) transfer switches*

IEC 62895:2017, *High voltage direct current (HVDC) power transmission – Cables with extruded insulation and their accessories for rated voltages up to 320 kV for land applications – Test methods and requirements*

ISO 22479:2019, *Corrosion of metals and alloys – Sulfur dioxide test in a humid atmosphere (fixed gas method)*

IEC/IEEE 65700-19-03:2014, *Bushings for DC application*

¹ Under preparation. Stage at the time of publication: IEC CDTS 62271-315:2024.