



TECHNICAL SPECIFICATION



**Marine energy – Wave, tidal and other water current converters –
Part 100: Electricity producing wave energy converters – Power performance
assessment**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 27.140

ISBN 978-2-8327-0039-6

Warning! Make sure that you obtained this publication from an authorized distributor.

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	10
3 Terms, definitions, symbols, units, and abbreviated terms	11
3.1 Terms and definitions.....	11
3.2 Symbols, units, and abbreviated terms.....	11
4 Sequence of work.....	14
5 Test site characterisation.....	14
5.1 General.....	14
5.2 Measurements	15
5.2.1 General	15
5.2.2 Wave measurement for wave power characterisation.....	15
5.2.3 Current measurement Tidal or ocean currents	16
5.2.4 Tidal measurement elevation	16
5.2.5 Bathymetric survey	16
5.2.6 Wind speeds.....	16
5.2.7 Calculation of wave spatial transfer model.....	16
5.2.8 Modelling of the test site.....	17
6 Methodology.....	17
6.1 General.....	17
6.2 Sample duration and frequency	18
6.3 Simultaneity	18
6.4 Data recording	18
6.4.1 Amount of data to be recorded.....	18
6.4.2 Data format and retaining	19
7 Measurement and data collection for wave data	19
7.1 General.....	19
7.2 WMI and calibration	19
7.3 Instrumentation location.....	19
7.2 WMI calibration.....	19
7.2.1 General	19
7.2.2 General	19
7.2.3 Direct measurement	20
7.2.4 Measures Measurements with spatial transfer model	20
7.2.5 Correction for WEC interference	20
7.3 Metocean data	20
7.4 Procedure for the calculation of derived parameters	20
8 WEC power output measurements	22
8.1 WEC electrical output terminals	22
8.2 Power measurement point.....	22
8.3 Power measurements	23
8.3.1 General	23
8.3.2 Limitations on power production	23
8.4 Instruments and calibration	23
9 Determination of power performance capture width matrix.....	24

9.1	General.....	24
9.2	Structure of the normalized power capture width matrix	24
9.2.1	Core structure.....	24
9.2.2	Sub-division of the normalized power capture width matrix	24
9.2.3	Calculation of the capture length width	24
9.2.4	Representation of the capture length matrix width per bin.....	25
9.3	Calculation of power matrix.....	24
10	Calculation of mean annual energy production (MAEP).....	24
10.1	General.....	24
10.2	Standard methodology.....	24
10.3	Alternative methodology.....	24
10.4	Completeness of the capture length matrix for MAEP.....	25
10	Reporting format.....	27
10.1	General.....	27
10.2	WEC description report	27
10.3	WEC test site report.....	27
10.4	Electrical grid and load report	28
10.5	Test equipment report.....	28
10.6	Measurement procedure report	29
10.7	Presentation of measured data	29
10.8	Deviations from the procedure	29
Annex A (informative)	Example production of a normalized power capture width matrix	30
A.1	General.....	30
A.2	Sample data	30
Annex B (normative)	Method for power loss compensation where the measurement point is located on shore.....	45
B.1	Single-line diagram	45
B.2	Cable loss compensation	46
Annex C (normative)	Evaluation of uncertainty.....	48
C.1	General.....	48
C.2	Uncertainty analysis.....	48
Annex D (normative)	Error analysis of the wave spatial transfer model	50
D.1	General.....	50
D.2	Overview.....	50
D.2.1	Validation procedure.....	50
D.2.2	Validation technique	50
Annex E (normative)	Wave energy converter power performance assessment at a second location using measured assessment data.....	52
E.1	General.....	52
E.2	Sequence of work	52
E.3	Limitations of this annex	53
E.4	Description of wave energy conversion (WEC) technology	53
E.5	Assess and characterize wave resource related to Location 1 and Location 2	53
E.5.1	General	53
E.5.2	Ambient condition	53
E.5.3	Wave resource at Location 1 and Location 2.....	54
E.6	WEC power capture data at Location 1	54
E.7	WEC model validation.....	54

E.7.1	General	54
E.7.2	Bin selection	54
E.7.3	Error per bin	54
E.7.4	Accounting for PTO losses	55
E.8	Modifications to the WEC	55
E.9	Calculate capture width matrix for use at Location 2	56
E.9.1	Evaluate appropriate dimensionality of the capture width matrix at Location 2.....	56
E.9.2	Calculate information for each bin of the capture width matrix	56
E.10	Quality assurance for cells based on measurements at Location 1	57
E.11	Complement capture width matrix to cover range of conditions at Location 2	57
E.11.1	Capture width matrix complementation requirement.....	57
E.11.2	Interpolation or extrapolation of the capture width matrix	57
E.11.3	Numerical model.....	57
E.11.4	Use of physical model.....	58
E.12	Calculate AEP at Location 2 using complemented capture width matrix and Location 2 resource data.....	58
E.13	Assessment of confidence	58
Annex F (informative)	Example analysis	59
F.1	General.....	59
F.2	Description of the WEC technology	59
F.3	Assess and characterize wave resource related to Location 1 and Location 2	60
F.4	Assess and characterize wave resource at Location 1	61
F.5	Assess and characterize wave resource at Location 2	62
F.6	WEC power capture data at Location 1	63
F.7	WEC model validation	64
F.8	Calculate capture width matrix for use at Location 2	66
F.8.1	Assess the appropriate dimensionality of the capture width matrix at Location 2.....	66
F.8.2	Calculate information for each bin of the capture width matrix	66
F.9	Perform quality assurance on capture width matrix for application at Location 2.....	67
F.10	Complement capture width matrix to cover range of conditions at Location 2	67
F.11	Calculate AEP at Location 2 using complemented capture width matrix and Location 2 resource data.....	68
F.12	Assessment of confidence	68
Annex G (informative)	Power take off efficiency	69
G.1	General.....	69
G.2	Absorbed power	69
G.3	WEC Power take off efficiency – location 1	70
G.4	Example calculation of PTO efficiency	70
G.5	Power take off efficiency – location 2	73
Bibliography	74
Figure 1	– Timeline of assessment.....	14
Figure 2	– Data flow diagram	18
Figure A.1	– Power scatter.....	32
Figure B.1	– Location options for metering equipment.....	45
Figure B.2	– Positive sequence cable model.....	46

Figure F.1 – The Wavestar prototype (diameter of each float is 5 m)..... 59

Figure F.2 – Map showing Location 1 Hanstholm and Location 2 Fjaltring..... 60

Figure F.3 – Location 1 wave energy flux matrix, Hantsholm, Denmark (based on measured data from Wavestar prototype Feb 2012 – Jan 2013)..... 62

Figure F.4 – Location 2 Wave Energy Flux Matrix, Buoy 2031 (Fjaltring, Denmark)..... 63

Figure F.5 – Wavestar prototype capture width matrix Location 1..... 64

Figure F.6 – Numerically modelled electrical power matrix, adapted from [3] 65

Figure F.7 – Model validation indicating percent difference in capture width between observations and model (model-observations) 66

Figure F.8 – Wavestar prototype capture width matrix for Location 2. Fjaltring, Denmark 68

Figure G.1 – Overview of Power Take Off System..... 69

Table 1 – Symbols, units, and abbreviated terms 12

Table A.1 – Sample data..... 30

Table A.2 – Average capture ~~length~~ width 34

Table A.3 – Standard deviation of capture ~~length~~ width 36

Table A.4 – Maximum capture ~~length~~ width 38

Table A.5 – Minimum capture capture ~~length~~ width 40

Table A.6 – Number of data samples 42

~~Table A.7 – Power matrix.....~~

Table C.1 – List of uncertainty components 48

Table F.1 – Locations 1 and 2, basic information 60

Table G.1 – Absorbed capture width 71

Table G.2 – PTO efficiency 72

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MARINE ENERGY – WAVE, TIDAL AND OTHER WATER CURRENT CONVERTERS –

Part 100: Electricity producing wave energy converters – Power performance assessment

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

This redline version of the official IEC Standard allows the user to identify the changes made to the previous edition IEC TS 62600-100:2012. A vertical bar appears in the margin wherever a change has been made. Additions are in green text, deletions are in strikethrough red text.

IEC TS 62600-100 has been prepared by IEC technical committee 114: Marine energy – Wave, tidal and other water current converters. It is a Technical Specification.

This second edition cancels and replaces the first edition published in 2012. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Incorporation of IEC TS 62600-102 as a series of annexes in this document
- b) Removal of the computation of annual energy production. This has been moved to IEC TS 62600-101.
- c) Modification to the list of terms definitions, symbols and units.
- d) Modification of the reporting section to align with IEC TS 62600-200

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
114/537/DTS	114/554/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62600 series, published under the general title *Marine Energy – Wave, tidal and other water current converters*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 62600, which is a Technical Specification, provides performance assessment methods for wave energy ~~Conversion Systems (WECS)~~ converters. A wave energy converter is a device which generates electricity using the action of water waves and delivers electricity to an electrical load.

Wave energy industry development is transitioning from preliminary stages to commercial production stages. Validated data gathering and processing techniques are important to improve existing technologies. This document will be subject to changes as data are collected and processed from testing of wave energy converters.

The expected users of the document include:

- Device developers who want to validate the performance of their wave energy converter.
- Investors who want to assess the performance of a device developer's wave energy converter.
- Project developers who want to assess the performance of their project against manufacturer's claims.
- Surveyors contracted to carry out the assessment.
- Conformity assessment, test laboratories, and certification.
- Project developers – income, return on investment
- Device developers – performance of device
- Utilities and investors – reliability/predictability of supply, return on investment
- Policy-makers and planners – usage of seascape, optimisation of resource, power supply issues
- Consultants to produce resource data/due diligence – compatible/readable data format

An essential element for any published Technical Specification or International Standard is to allow an opportunity to provide feedback on its contents to the appropriate TC 114 Working Group. TC 114 utilizes a standard methodology to allow this.

To submit feedback such as proposed changes, corrections and/or improvements to this document, please send an email to the TC 114 Chair using the Contact TC 114 Officers feature on the IEC TC 114 Dashboard, accessible at www.iec.ch/tc114. On the right side of the Dashboard under Further information select the link to contact the TC 114 Officers. On the subsequent page find and select the Send Email link for the Chair to access the email tool.

Complete all the required elements within the email pop-up. For the Subject field please include the document title and edition you are providing feedback for (ex: feedback for TS 62600-1 ED2). In the Message field, include text which summarizes your feedback and note if further information can be made available (note attachments are not allowed). The Chair may request added information as needed before forwarding the submission to the remaining TC 114 Officers for review and then to the appropriate Working Group for their consideration.

MARINE ENERGY – WAVE, TIDAL AND OTHER WATER CURRENT CONVERTERS –

Part 100: Electricity producing wave energy converters – Power performance assessment

1 Scope

Wave Energy Converters (WEC) are designed to operate efficiently at different locations. Systematic methods are used to evaluate the power performance of a WEC at a second location (hereinafter Location 2) based on power performance assessment at a first location (hereinafter Location 1). The degree of similarity of the measured WEC (WEC 1) and the metocean conditions at Location 1 to the secondary WEC (WEC 2) at Location 2 determine the methodology and the applicability of this document.

~~This part of IEC 62600, which is a Technical Specification, provides a method for assessing the electrical power production performance of a Wave Energy Converter (WEC), based on the performance at a testing site.~~

This document applied in conjunction with the IEC Technical Specification on wave energy resource assessment and characterization (IEC TS 62600-101), provides a method for estimation of the mean annual energy production of a WEC, assessing the electrical power production performance of a single, non-array, wave energy converter, at Location 2 based on the performance at Location 1.

The scope of this document includes:

- a) All wave energy converters that produce electrical power from wave energy.
- b) All sea resource zones (near and offshore, deep and shallow water).
- c) Capture width matrix transposition from one location to another.
- d) Limitation on the changes that are allowed to the WEC and the specification of the location.
- e) Wave data required at Location 2, as a minimum the requirements found in IEC TS 62600-101.
- f) Development of the capture width matrix at Location 2.
- g) Validation of the capture width matrix at Location 2.
- h) Assessment of uncertainties in the derived performance parameters at Location 2.
- i) Requirements for the allowable power performance transfer by geometric, kinematic and dynamic similarity.
- j) Requirements for the allowable incorporation of additional empirical model data.
- k) Requirements for the allowable incorporation of additional numerical model data.
- l) The document applies to commercial scale wave energy converters that are:
 - 1) compliantly moored.
 - 2) tautly moored.
 - 3) bottom mounted.
 - 4) shore mounted.

The scope of this document does not include:

- ~~a) WECs that produce other forms of energy unless this energy is converted into electrical energy;~~

- a) Wave energy converters that produce nonelectrical energy.
- b) Resource assessment.
- c) Scaled devices in test facilities (tank or scaled sea conditions) where any scaling would ~~need to~~ be carried out to extrapolate results for a full-scale device.
- d) Power quality issues.
- e) Environmental issues.
- ~~f) power matrix transposition from one location to another.~~
- f) Operation and maintenance.
- g) Annual energy production (AEP).

This document provides a systematic method which includes:

- measurement of WEC ~~power output~~ capture width in a range of sea states.
- ~~WEC power matrix development;~~
- transposition of capture width from one location to a second location.
- an agreed framework for reporting the results of ~~power~~ capture width and wave measurements.
- estimate of the capture width of a modified WEC at Location 2. This work would include the development of parameters for the modified WEC for the second location.

This document provides:

- guidance on the use of observations from Location 1.
- methods for assessing and reporting the validity of numerical and physical models.
- limits on the permissible changes to the WEC between Locations 1 and 2.
- limits on the use of data fitting techniques, and
- requirements for reporting.

The wave power industry is at an early stage of development. There is little practical experience with field-scale WECs deployment. Because of this, the present document will be subject to change as more data is collected and experience with wave energy converters develops.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

~~IEC 60044-1, Instrument transformers – Part 1: Current transformers~~

IEC 60688, *Electrical measuring transducers for converting AC and DC. electrical quantities to analogue or digital signals*

~~IEC 61000-3 (all parts), Electromagnetic compatibility (EMC) – Part 3: Limits~~

IEC 61869-1, *Instrument transformers – Part 1: General requirements*

IEC 61869-2, *Instrument transformers – Part 2: Additional Requirements for current transformers*

IEC 61869-3, *Instrument transformers – Part 3: Additional requirements for inductive voltage transformers*

IEC TS 62600-3, *Marine energy – Wave, tidal and other water current converters – Part 3: Measurement of mechanical loads*

IEC TS 62600-101:2015, *Marine energy – Wave, tidal and other water current converters – Part 101: Wave energy resource assessment and characterization*

IEC TS 62600-103, *Marine energy – Wave, tidal and other water current converters – Part 103: Guidelines for the early stage development of wave energy converters – Best practices and recommended procedures for the testing of pre-prototype devices*

ISO/IEC Guide 98-1:~~2009~~, *Uncertainty of measurement – Part 1: Introduction to the expression of uncertainty in measurement*

ISO/IEC Guide 98-3:~~2008~~, *Uncertainty of measurement – Part 3: Guide to the expression of uncertainty in measurement (GUM:1995)*

ISO 8601, *Data elements and interchange formats – Information interchange – Representation of dates and times*

ISO 19901-1, *Petroleum and natural gas industries – Specific requirements for offshore structures – Part 1: Metocean design and operating considerations*

~~*EquiMar: Protocols for the equitable assessment of marine energy converters, Part II, Chapters I.A.1 through I.A.5, Editors: David Ingram, George Smith, Claudio Bittencourt Ferreira, Helen Smith. European Commission 7th framework programme grant agreement number 213380, First Edition 2011*~~

~~*NDBC:2009, Technical Document 09-02, Handbook of automated data quality control checks and procedures. National Data Buoy Center, August 2009*~~

TECHNICAL SPECIFICATION



**Marine energy – Wave, tidal and other water current converters –
Part 100: Electricity producing wave energy converters – Power performance
assessment**

CONTENTS

FOREWORD.....	6
INTRODUCTION.....	8
1 Scope.....	9
2 Normative references	10
3 Terms, definitions, symbols, units, and abbreviated terms	11
3.1 Terms and definitions.....	11
3.2 Symbols, units, and abbreviated terms.....	11
4 Sequence of work.....	13
5 Test site characterisation.....	14
5.1 General.....	14
5.2 Measurements	14
5.2.1 General	14
5.2.2 Wave characterisation	14
5.2.3 Tidal or ocean currents	15
5.2.4 Tidal elevation	15
5.2.5 Bathymetric survey	15
5.2.6 Wind speeds.....	16
5.2.7 Calculation of wave spatial transfer model.....	16
5.2.8 Modelling of the test site.....	16
6 Methodology.....	16
6.1 General.....	16
6.2 Sample duration.....	17
6.3 Simultaneity	17
6.4 Data recording	17
6.4.1 Amount of data to be recorded.....	17
6.4.2 Data format and retaining	18
7 Measurement and data collection for wave data	18
7.1 General.....	18
7.2 WMI calibration.....	18
7.2.1 General	18
7.2.2 General	18
7.2.3 Direct measurement	18
7.2.4 Measurements with spatial transfer model	18
7.2.5 Correction for WEC interference	19
7.3 Metocean data	19
7.4 Procedure for the calculation of derived parameters	19
8 WEC power output measurements.....	21
8.1 WEC electrical output terminals	21
8.2 Power measurement point.....	21
8.3 Power measurements	21
8.3.1 General	21
8.3.2 Limitations on power production	21
8.4 Instruments and calibration	22
9 Determination of capture width matrix.....	22
9.1 General.....	22
9.2 Structure of the capture width matrix.....	22

- 9.2.1 Core structure..... 22
- 9.2.2 Sub-division of the normalized capture width matrix..... 23
- 9.2.3 Calculation of the capture width..... 23
- 9.2.4 Representation of the capture width per bin..... 23
- 10 Reporting format..... 23
 - 10.1 General..... 23
 - 10.2 WEC description report..... 24
 - 10.3 WEC test site report..... 24
 - 10.4 Electrical grid and load report 25
 - 10.5 Test equipment report..... 25
 - 10.6 Measurement procedure report 25
 - 10.7 Presentation of measured data 25
 - 10.8 Deviations from the procedure 26
- Annex A (informative) Example production of a normalized capture width matrix..... 27
 - A.1 General..... 27
 - A.2 Sample data 27
- Annex B (normative) Method for power loss compensation where the measurement point is located on shore..... 33
 - B.1 Single-line diagram 33
 - B.2 Cable loss compensation 34
- Annex C (normative) Evaluation of uncertainty..... 36
 - C.1 General..... 36
 - C.2 Uncertainty analysis..... 36
- Annex D (normative) Error analysis of the wave spatial transfer model 38
 - D.1 General..... 38
 - D.2 Overview..... 38
 - D.2.1 Validation procedure..... 38
 - D.2.2 Validation technique 38
- Annex E (normative) Wave energy converter power performance assessment at a second location using measured assessment data 40
 - E.1 General..... 40
 - E.2 Sequence of work 40
 - E.3 Limitations of this annex 41
 - E.4 Description of wave energy conversion (WEC) technology 41
 - E.5 Assess and characterize wave resource related to Location 1 and Location 2..... 41
 - E.5.1 General 41
 - E.5.2 Ambient condition 41
 - E.5.3 Wave resource at Location 1 and Location 2..... 42
 - E.6 WEC power capture data at Location 1 42
 - E.7 WEC model validation..... 42
 - E.7.1 General 42
 - E.7.2 Bin selection..... 42
 - E.7.3 Error per bin 42
 - E.7.4 Accounting for PTO losses 43
 - E.8 Modifications to the WEC..... 43
 - E.9 Calculate capture width matrix for use at Location 2 44
 - E.9.1 Evaluate appropriate dimensionality of the capture width matrix at Location 2..... 44
 - E.9.2 Calculate information for each bin of the capture width matrix 44

E.10	Quality assurance for cells based on measurements at Location 1	45
E.11	Complement capture width matrix to cover range of conditions at Location 2	45
E.11.1	Capture width matrix complementation requirement	45
E.11.2	Interpolation or extrapolation of the capture width matrix	45
E.11.3	Numerical model	45
E.11.4	Use of physical model	46
E.12	Calculate AEP at Location 2 using complemented capture width matrix and Location 2 resource data	46
E.13	Assessment of confidence	46
Annex F (informative)	Example analysis	47
F.1	General	47
F.2	Description of the WEC technology	47
F.3	Assess and characterize wave resource related to Location 1 and Location 2	48
F.4	Assess and characterize wave resource at Location 1	49
F.5	Assess and characterize wave resource at Location 2	50
F.6	WEC power capture data at Location 1	51
F.7	WEC model validation	52
F.8	Calculate capture width matrix for use at Location 2	54
F.8.1	Assess the appropriate dimensionality of the capture width matrix at Location 2	54
F.8.2	Calculate information for each bin of the capture width matrix	54
F.9	Perform quality assurance on capture width matrix for application at Location 2	55
F.10	Complement capture width matrix to cover range of conditions at Location 2	55
F.11	Calculate AEP at Location 2 using complemented capture width matrix and Location 2 resource data	56
F.12	Assessment of confidence	56
Annex G (informative)	Power take off efficiency	57
G.1	General	57
G.2	Absorbed power	57
G.3	WEC Power take off efficiency – location 1	58
G.4	Example calculation of PTO efficiency	58
G.5	Power take off efficiency – location 2	61
Bibliography	62
Figure 1	– Timeline of assessment	14
Figure 2	– Data flow diagram	17
Figure A.1	– Power scatter	28
Figure B.1	– Location options for metering equipment	33
Figure B.2	– Positive sequence cable model	34
Figure F.1	– The Wavestar prototype (diameter of each float is 5 m)	47
Figure F.2	– Map showing Location 1 Hanstholm and Location 2 Fjaltring	48
Figure F.3	– Location 1 wave energy flux matrix, Hantsholm, Denmark (based on measured data from Wavestar prototype Feb 2012 – Jan 2013)	50
Figure F.4	– Location 2 Wave Energy Flux Matrix, Buoy 2031 (Fjaltring, Denmark)	51
Figure F.5	– Wavestar prototype capture width matrix Location 1	52
Figure F.6	– Numerically modelled electrical power matrix, adapted from [3]	53

Figure F.7 – Model validation indicating percent difference in capture width between observations and model (model-observations) 54

Figure F.8 – Wavestar prototype capture width matrix for Location 2. Fjaltring, Denmark 56

Figure G.1 – Overview of Power Take Off System 57

Table 1 – Symbols, units, and abbreviated terms 11

Table A.1 – Sample data 27

Table A.2 – Average capture width 29

Table A.3 – Standard deviation of capture width 30

Table A.4 – Maximum capture width 30

Table A.5 – Minimum capture width 31

Table A.6 – Number of data samples 32

Table C.1 – List of uncertainty components 36

Table F.1 – Locations 1 and 2, basic information 48

Table G.1 – Absorbed capture width 59

Table G.2 – PTO efficiency 60

INTERNATIONAL ELECTROTECHNICAL COMMISSION

MARINE ENERGY – WAVE, TIDAL AND OTHER WATER CURRENT CONVERTERS –

Part 100: Electricity producing wave energy converters – Power performance assessment

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) IEC draws attention to the possibility that the implementation of this document may involve the use of (a) patent(s). IEC takes no position concerning the evidence, validity or applicability of any claimed patent rights in respect thereof. As of the date of publication of this document, IEC had not received notice of (a) patent(s), which may be required to implement this document. However, implementers are cautioned that this may not represent the latest information, which may be obtained from the patent database available at <https://patents.iec.ch>. IEC shall not be held responsible for identifying any or all such patent rights.

IEC TS 62600-100 has been prepared by IEC technical committee 114: Marine energy – Wave, tidal and other water current converters. It is a Technical Specification.

This second edition cancels and replaces the first edition published in 2012. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) Incorporation of IEC TS 62600-102 as a series of annexes in this document
- b) Removal of the computation of annual energy production. This has been moved to IEC TS 62600-101.

- c) Modification to the list of terms definitions, symbols and units.
- d) Modification of the reporting section to align with IEC TS 62600-200

The text of this Technical Specification is based on the following documents:

Draft	Report on voting
114/537/DTS	114/554/RVDTS

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this Technical Specification is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 62600 series, published under the general title *Marine Energy – Wave, tidal and other water current converters*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn, or
- revised.

IMPORTANT – The "colour inside" logo on the cover page of this document indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

This part of IEC 62600, which is a Technical Specification, provides performance assessment methods for wave energy converters. A wave energy converter is a device which generates electricity using the action of water waves and delivers electricity to an electrical load.

Wave energy industry development is transitioning from preliminary stages to commercial production stages. Validated data gathering and processing techniques are important to improve existing technologies. This document will be subject to changes as data are collected and processed from testing of wave energy converters.

The expected users of the document include:

- Device developers who want to validate the performance of their wave energy converter.
- Investors who want to assess the performance of a device developer's wave energy converter.
- Project developers who want to assess the performance of their project against manufacturer's claims.
- Surveyors contracted to carry out the assessment.
- Conformity assessment, test laboratories, and certification.
- Project developers – income, return on investment
- Device developers – performance of device
- Utilities and investors – reliability/predictability of supply, return on investment
- Policy-makers and planners – usage of seascape, optimisation of resource, power supply issues
- Consultants to produce resource data/due diligence – compatible/readable data format

An essential element for any published Technical Specification or International Standard is to allow an opportunity to provide feedback on its contents to the appropriate TC 114 Working Group. TC 114 utilizes a standard methodology to allow this.

To submit feedback such as proposed changes, corrections and/or improvements to this document, please send an email to the TC 114 Chair using the Contact TC 114 Officers feature on the IEC TC 114 Dashboard, accessible at www.iec.ch/tc114. On the right side of the Dashboard under Further information select the link to contact the TC 114 Officers. On the subsequent page find and select the Send Email link for the Chair to access the email tool.

Complete all the required elements within the email pop-up. For the Subject field please include the document title and edition you are providing feedback for (ex: feedback for TS 62600-1 ED2). In the Message field, include text which summarizes your feedback and note if further information can be made available (note attachments are not allowed). The Chair may request added information as needed before forwarding the submission to the remaining TC 114 Officers for review and then to the appropriate Working Group for their consideration.

MARINE ENERGY – WAVE, TIDAL AND OTHER WATER CURRENT CONVERTERS –

Part 100: Electricity producing wave energy converters – Power performance assessment

1 Scope

Wave Energy Converters (WEC) are designed to operate efficiently at different locations. Systematic methods are used to evaluate the power performance of a WEC at a second location (hereinafter Location 2) based on power performance assessment at a first location (hereinafter Location 1). The degree of similarity of the measured WEC (WEC 1) and the metocean conditions at Location 1 to the secondary WEC (WEC 2) at Location 2 determine the methodology and the applicability of this document.

This document applied in conjunction with the IEC Technical Specification on wave energy resource assessment and characterization (IEC TS 62600-101), provides a method for estimation of the mean annual energy production of a WEC, assessing the electrical power production performance of a single, non-array, wave energy converter, at Location 2 based on the performance at Location 1.

The scope of this document includes:

- a) All wave energy converters that produce electrical power from wave energy.
- b) All sea resource zones (near and offshore, deep and shallow water).
- c) Capture width matrix transposition from one location to another.
- d) Limitation on the changes that are allowed to the WEC and the specification of the location.
- e) Wave data required at Location 2, as a minimum the requirements found in IEC TS 62600-101.
- f) Development of the capture width matrix at Location 2.
- g) Validation of the capture width matrix at Location 2.
- h) Assessment of uncertainties in the derived performance parameters at Location 2.
- i) Requirements for the allowable power performance transfer by geometric, kinematic and dynamic similarity.
- j) Requirements for the allowable incorporation of additional empirical model data.
- k) Requirements for the allowable incorporation of additional numerical model data.
- l) The document applies to commercial scale wave energy converters that are:
 - 1) compliantly moored.
 - 2) tautly moored.
 - 3) bottom mounted.
 - 4) shore mounted.

The scope of this document does not include:

- a) Wave energy converters that produce nonelectrical energy.
- b) Resource assessment.
- c) Scaled devices in test facilities (tank or scaled sea conditions) where any scaling would be carried out to extrapolate results for a full-scale device.
- d) Power quality issues.

- e) Environmental issues.
- f) Operation and maintenance.
- g) Annual energy production (AEP).

This document provides a systematic method which includes:

- measurement of WEC capture width in a range of sea states.
- transposition of capture width from one location to a second location.
- an agreed framework for reporting the results of capture width and wave measurements.
- estimate of the capture width of a modified WEC at Location 2. This work would include the development of parameters for the modified WEC for the second location.

This document provides:

- guidance on the use of observations from Location 1.
- methods for assessing and reporting the validity of numerical and physical models.
- limits on the permissible changes to the WEC between Locations 1 and 2.
- limits on the use of data fitting techniques, and
- requirements for reporting.

The wave power industry is at an early stage of development. There is little practical experience with field-scale WECs deployment. Because of this, the present document will be subject to change as more data is collected and experience with wave energy converters develops.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60688, *Electrical measuring transducers for converting AC and DC. electrical quantities to analogue or digital signals*

IEC 61869-1, *Instrument transformers – Part 1: General requirements*

IEC 61869-2, *Instrument transformers – Part 2: Additional Requirements for current transformers*

IEC 61869-3, *Instrument transformers – Part 3: Additional requirements for inductive voltage transformers*

IEC TS 62600-3, *Marine energy – Wave, tidal and other water current converters – Part 3: Measurement of mechanical loads*

IEC TS 62600-101:2015, *Marine energy – Wave, tidal and other water current converters – Part 101: Wave energy resource assessment and characterization*

IEC TS 62600-103, *Marine energy – Wave, tidal and other water current converters – Part 103: Guidelines for the early stage development of wave energy converters – Best practices and recommended procedures for the testing of pre-prototype devices*

ISO/IEC Guide 98-1, *Uncertainty of measurement – Part 1: Introduction to the expression of uncertainty in measurement*

ISO/IEC Guide 98-3, *Uncertainty of measurement – Part 3: Guide to the expression of uncertainty in measurement* (GUM:1995)

ISO 8601, *Data elements and interchange formats – Information interchange – Representation of dates and times*

ISO 19901-1, *Petroleum and natural gas industries – Specific requirements for offshore structures – Part 1: Metocean design and operating considerations*