



TECHNICAL SPECIFICATION



**Mechanical structures for electronic equipment – Thermal management for cabinets in accordance with IEC 60297 and IEC 60917 series –
Part 1: Design guide: Interface dimension and provision for thermoelectrical cooling systems (Peltier effect)**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

T

ICS 31.240

ISBN 978-2-88910-772-8

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references.....	7
3 Arrangement overview.....	7
4 Mounting location 1: cabinet with inside or outside mounted thermoelectrical cooling system in a vertical alignment.....	8
4.1 Cabinet with inside mounted thermoelectrical cooling system in a vertical alignment.....	8
4.1.1 General.....	8
4.1.2 Overview.....	8
4.1.3 Performance guideline for cabinets with inside or outside mounted thermoelectrical cooling system.....	10
4.2 Cabinet with inside mounted thermoelectrical cooling system in a horizontal alignment.....	12
5 Mounting location 2: cabinet with top mounted thermoelectrical cooling system for the cooling of a whole cabinet.....	13
5.1 Overview.....	13
5.2 Cooling performance in cabinets with top mounted thermoelectrical cooling systems.....	14
6 Mounting location 3: cabinet with inbuilt thermoelectrical cooling system for hot spot cooling.....	14
6.1 Overview.....	14
6.2 Cooling performance for an inbuilt thermoelectrical cooling system for hot spot cooling.....	16
7 Remark.....	16
Annex A (informative) Heat management under environmental aspects.....	18
Bibliography.....	23
Figure 1 – Arrangement overview.....	8
Figure 2 – Mounting location 1.....	9
Figure 3 – Mounting location 1: arrangement of two cabinets with inside mounted Peltier system and minimized distance W_1	10
Figure 4 – Performance guideline for cabinets with inside mounted thermoelectrical cooling system.....	11
Figure 5 – Mounting location 1a: cabinet with side mounted thermoelectrical cooling system in a horizontal alignment.....	12
Figure 6 – Mounting location 2: cabinet with top mounted thermoelectrical cooling system.....	13
Figure 7 – Performance guideline for a top mounted thermoelectrical cooling system.....	14
Figure 8 – Mounting location 3.....	15
Figure 9 – Performance guideline for inbuilt thermoelectrical cooling system for hot spot cooling.....	16
Figure A.1 – Current CO ₂ emission situation.....	19
Figure A.2 – Changes in greenhouse gases from ice-core and modern data [5].....	19
Figure A.3 – Radiative forcing of climate between 1750 and 2005 [4].....	20

Figure A.4 – Coefficient of performance depending on the cooling power at the boundary conditions of $T_a = 50\text{ °C}$	21
Figure A.5 – Electrical power usage of compressor cooling unit versus Peltier cooling unit at given ambient temperature and given heating dissipation to keep the internal temperature fixed.....	22
Table A.1 – Advantages and disadvantages of different cooling systems	22

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MECHANICAL STRUCTURES FOR ELECTRONIC EQUIPMENT –
THERMAL MANAGEMENT FOR CABINETS IN ACCORDANCE
WITH IEC 60297 AND IEC 60917 SERIES –****Part 1: Design guide: Interface dimension and provision
for thermoelectrical cooling systems (Peltier effect)**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 62610-1, which is a technical specification, has been prepared by subcommittee 48D: Mechanical structures for electronic equipment, of IEC technical committee 48: Electromechanical components and mechanical structures for electronic equipment.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
48D/393/DTS	48D/405/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62610 series can be found, under the general title *Mechanical structures for electronic equipment – Thermal management for cabinets in accordance with IEC 60297 and IEC 60917 series*, on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this standard may be issued at a later date.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

According to the Kyoto Protocol and to the directives of the European Parliament and of the Council, the usage of coolants with high potential for environmental pollution and global warming (Global Warming Potential (GWP) factor) is to be avoided.

The most promising alternatives to compressor cooling with e.g. R 134a are compressor cooling with CO₂, active cooling based on the Peltier effect and absorption cooling systems. Each of these techniques has its advantages and disadvantages.

The compressor cooling with CO₂ at the current state is more or less efficient, but high installation costs due to working pressures up to 100 bars makes this technique less interesting. Another disadvantage of CO₂ cooling systems occurs out of the physical properties of this coolant and requires additional cooling power to run this process. This fact reduces the degree of efficiency enormously.

The Peltier-effect seems to be very promising as the cooling effect is highly dependent of the properties of the material. Newly tested materials based on either porous materials or nano-structures show an improvement of the degree of efficiency. Furthermore, Peltier techniques do not need any kind of coolant and the only moving parts are the fans.

The absorption technique is a very intelligent way for cooling, but it is only profitable in combination with a heat-regenerator what makes absorption cooling system only feasible in very few applications.

For more details on mentioned alternatives for cooling, please see Annex A.

With respect to the demands of industry concerning high heat density/hotspots cooling, available space for the cooling systems, adapting to existing infrastructures, noise emission and respectively to the fact that conventional coolants like R 134a need to be replaced, this technical specification was initiated for the definition of dimensional interfaces and performances guidelines for thermoelectrical cooling systems based on the Peltier effect.

Three different arrangements for thermoelectrical cooling systems within cabinets, called “mounting locations”, have been regarded where locations 1 and 2 are feasible for cooling a whole cabinet and location 3 is for hotspot cooling inside the cabinet.

Below is the definition of each mounting location for thermoelectrical cooling systems within cabinets:

- mounting location 1: cabinet with inside or outside mounted thermoelectrical cooling system for the cooling of a whole cabinet;
- mounting location 2: cabinet with top mounted thermoelectrical cooling system for the cooling of a whole cabinet;
- mounting location 3: cabinet with inbuilt thermoelectrical cooling system in form of a subrack for hot spot cooling.

For a clear definition of interface dimensions and cooling performance guidelines, only cabinets from the IEC 60297 (19 inch) and IEC 60917 (25 mm) series have been regarded.

MECHANICAL STRUCTURES FOR ELECTRONIC EQUIPMENT – THERMAL MANAGEMENT FOR CABINETS IN ACCORDANCE WITH IEC 60297 AND IEC 60917 SERIES –

Part 1: Design guide: Interface dimension and provision for thermoelectrical cooling systems (Peltier effect)

1 Scope

This Technical Specification provides guidelines for the installation of thermoelectrical cooling systems (Peltier effect) within cabinets of the IEC 60297 (19 inch) and IEC 60917 (25 mm) series.

The cooling performance is in direct relation with the mounting location within a cabinet.

Three typical mounting locations are identified:

- mounting location 1: cabinet with inside or outside mounted thermoelectrical cooling system for the cooling of a whole cabinet;
- mounting location 2: cabinet with top mounted thermoelectrical cooling system for the cooling of a whole cabinet;
- mounting location 3: cabinet with inbuilt thermoelectrical cooling system in form of a subrack for hot spot cooling.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60297 (all parts), *Mechanical structures for electronic equipment – Dimensions of mechanical structures of the 482,6 mm (19 in) series*

IEC 60917 (all parts), *Modular order for the development of mechanical structures for electronic equipment practices*