

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC TR 62271-305 Edition 1.0 2009-11

High-voltage switchgear and controlgear –

**Part 305: Capacitive current switching capability of air-insulated
Disconnectors for rated voltages above 52 kV**

CORRIGENDUM 1

5.6 Test circuit

Replace the existing second paragraph after Figure 1 by the following new paragraph:

For each test current, the ratio C_S/C_L should be agreed between the manufacturer and the user.